



TAMIL NADU POLLUTION CONTROL BOARD

From The Member Secretary Tamil Nadu Pollution Control Board, Guindy Chennai-600 032.	To The Additional Chief Secretary to Govt., Environment, Climate Change and Forests Department, Government of Tamil Nadu, Secretariat, Chennai- 600 009.
---	---

Lr.No.TNPCB/DDL/F-6849/PRS-MPR/2019/dated: 29.07.2022.

Madam,

Sub: TNPCB-Submission of Revised Monthly Progress Report for the month of **MAY 2022** -Regarding.

Ref: 1) CPCB Lr.No.F.No.A-14011/OA 673/2020-WQM-I/ 12178/
dt.4.2.2020.
2) T.O.Lr.No.TNPCB/DDL/F.6849/PRS/2019 Dt : 08.07.2022

With reference to the Government letter 1st cited, I submit monthly progress report on action plans for the Polluted River Stretches for the month of **MAY 2022** in Tamil Nadu for kind perusal.

I request that the above report may be forwarded to the Executive Director-Technical, National Mission for Clean Ganga, Ministry of Jal Shakthi, Government of India with a copy to Central Pollution Control Board, New Delhi.

This is submitted for favour of kind information and necessary action please.

Encl: As above

for MemberSecretary

Advance copy submitted to:

✓ The Executive Director-Technical, NMCG, (Ministry of Jal Shakthi, Department of Water Resources, River Development & Ganga Rejuvenation, Government of India), First floor, Major Dhyani Chand National Stadium, India Gate, New Delhi-110002.

Copy to: File

No. 76, MOUNT SALAI, GUINDY, CHENNAI - 600 032.

Tel : 044-22353134 - 139 Fax : 044-22353068

Email : tnpcb-chn@gov.in Web : tnpcb.gov.in

Format for Submission of Monthly Progress Report by the State of

Tamil Nadu

(Hon'ble NGT in the matter of OA No.673/2018 dated 06.12.2019)

MAY 2022

Sl. No.	Progress report submitted by department	Enclosures
1.	• Commissionerate of Municipal Administration (DMA), • Chennai Metro water Supply & Sewage Board (CMWSSB), and • Greater Chennai Corporation (GCC)	Enclosed vide Annexure –I
2.	Director of Town Panchayat (DTP)	Enclosed vide Annexure –II
3.	Directorate Rural Development & Panchayat Raj	Enclosed vide Annexure- III
4.	Public Works Department PWD & WRD	Enclosed vide Annexure –IV
5.	Tamil Nadu Pollution Control Board	Enclosed vide Annexure –V

Monthly Progress Report in the NGT Matter
OA No. 673 of 2018 (in compliance to NGT order dated 24.09.2020)

Month: MAY 2022

Overall status of the state :

- I.** Total Population: 72.14 million
Urban Population: 34.95 million
Rural Population: 37.19 million
- II. a.** Estimated Sewage Generation (MLD): 3938.29 MLD (State)
b. Estimated Sewage Generation (MLD): 400.47 MLD (PRS)

III. Details of Sewage Treatment Plant:

S.No.	Details of Sewage Treatment Plant	State	PRS
1.	Existing No. of STPs and Treatment Capacity (in MLD)	82 1765.98	14 298.38
2.	MLD of sewage being treated through Alternate technology	752	1.56
3.	Existing No. of FSTP and Capacity (in MLD)	25 0.724	6 0.06
4.	Under Construction STPs (MLD)	871	67.10
5.	Gap in Treatment Capacity in MLD	548.586	33.37
6.	Capacity Utilization of existing STPs	951.59	135.7
7.	No. of Operational STPs	82	14
8.	No. of Complying STPs	82	14
9.	No. of Non-complying STPs	Nil	Nil

Details of each existing STPs in Tamil Nadu & PRS

No.	Location	Existing STP Capacity (MLD)	Capacity being utilized (MLD)	Operational Status of STP	Compliance Status of STP
	CMWSSB				
1.	Nesapakkam Zone –IV	23	15.35	Operational	Complied
2.	Koyambedu Zone – III	34	30.86	Operational	Complied
3.	Kodungaiyur Zone II	80	60.71	Operational	Complied
4.	Kodungaiyur Zone I	80	61.9	Operational	Complied
5.	Perungudi Zone - V	12	10.37	Operational	Complied
6.	Koyambedu Zone - III	60	-	Rehabilitation	Complied
7.	Kodungaiyur Zone I& II	110	86.75	Operational	Complied

8.	Nesapakkam Zone –IV	40	23.80	Operational	Complied
9.	Perungudi Zone-V	54	45.04	Operational	Complied
10	Perungudi Zone-V	60	49.22	Operational	Complied
11	Nesapakkam Zone –IV	54	51.42	Operational	Complied
12	Koyambedu Zone – III	120	88.86	Operational	Complied
13	Sholinganallur	18	8.36	Operational	Complied
Total (13 Nos)		745	532.64	.	
DMA					
14.	Coimbatore- 1	70.0	35.0	Operational	Complied
15.	Coimbatore- 2	60.0	6.0	Operational	Complied
16.	Vellore	10.28	8.0	Operational	Complied
17.	Dindigul	13.65	3.0	Operational	Complied
18.	Avadi	36.0	6.0	Operational	Complied
19.	Avadi	4.0	1.0	Operational	Complied
20.	Madurai-1	125.0	24.0	Operational	Complied
21.	Madurai-2	45.70	15.0	Operational	Complied
22.	Thanjavur	28.05	14.15	Operational	Complied
23.	Tiruppur	15.0	8.50	Operational	Complied
24.	Cuddalore	12.25	6.70	Operational	Complied
25.	Kanchipuram	14.70	14.70	Operational	Complied
26.	Maraimalai Nagar	2.20	2.20	Operational	Complied
27.	Tiruvallur	6.20	5.50	Operational	Complied
28.	Chidambaram	9.44	6.10	Operational	Complied
29.	Thiruvannamalai	8.70	4.75	Operational	Complied
30.	Viluppuram – Kakuppam	9.0	7.0	Operational	Complied
31.	Viluppuram -Erumanthangal	3.50	1.80	Operational	Complied
32.	Arakkonam	11.04	2.0	Operational	Complied

33.	Thirupathur	11.43	3.0	Operational	Complied
34.	Bodinayakkanur	12.08	4.0	Operational	Complied
35.	Chinnamanur	3.99	3.72	Operational	Complied
36.	Periyakulam	5.47	4.0	Operational	Complied
37.	Ramanathpuram	7.0	5.80	Operational	Complied
38.	Rasipuram	6.96	3.30	Operational	Complied
39.	Theni-Allinagaram	12.05	9.50	Operational	Complied
40.	Sivagangai	4.92	2.0	Operational	Complied
41.	Dharmapuri	4.86	3.50	Operational	Complied
42.	Karur	15.0	5.63	Operational	Complied
43.	Krishnagiri	12.34	8.0	Operational	Complied
44.	Namakkal	5.0	5.0	Operational	Complied
45.	Nagapattinam STP-1	9.63	4.40	Operational	Complied
46.	Nagapattinam STP-2	2.69	1.10	Operational	Complied
47.	Tiruvarur	6.92	4.10	Operational	Complied
48.	Ariyalur	4.16	1.50	Operational	Complied
49.	Pudukkottai	10.62	6.0	Operational	Complied
50.	Perambalur	4.20	3.60	Operational	Complied
51.	Udhagamandalam	5.0	4.0	Operational	Complied
52.	Udumalaipet	7.81	4.0	Operational	Complied
53.	Virudhunagar	7.65	3.80	Operational	Complied
54.	Tambaram	30.0	3.0	Under trial run	Complied
55.	Tuticorin	28.0	2.50	Under trial run	Complied
56.	Thiruchendur	3.90	1.80	Operational	Complied
57.	Ulunderpettai	3.15	1.0	Under trial run	Complied
58.	Pollachi	11.25	0.5	Under trial run	Complied
59.	Tiruchirappalli	58.0	58.0	Operational	Complied

60.	Salem - Vellakuttai STP	13.0	9.0	Operational	Complied
61.	Salem - Anaimeedu STP	6.0	5.0	Operational	Complied
62.	Salem - Mankuttai STP	35.0	4.0	Operational	Complied
63.	Salem - Vandipettai STP	44.0	1.0	Operational	Complied
64.	Tirunelveli	24.20	10.0	Operational	Complied
65.	Erode	50.55	27.0	Operational	Complied
66.	Mettur STP-1	0.82	0.50	Operational	Complied
67.	Mettur STP-2	0.92	0.15	Operational	Complied
68.	Mettur STP-3	5.45	2.20	Operational	Complied
69.	Kumbakonam	17.0	12.50	Operational	Complied
70.	Mayiladuthurai	5.85	5.85	Operational	Complied
71.	Sathiyamanagalam	4.08	0.50	Under trial run	Complied
72.	Mettupalayam	8.65	1.0	Under trial run	Complied
	Total - 59 Nos.	994.31	406.85		
	CTP				
73.	Mamallapuram TP	2.34	1.0	Operational	Complied
74.	Orathanadu TP	2.30	1.30	Operational	Complied
75.	Palanichettypatti TP	2.80	2.80	Operational	Complied
76.	Thirumazisai TP	3.0	1.0	Operational	Complied
77.	Velankanni TP	2.33	1.0	Operational	Trial Run
78.	Manachanallur TP	6.41	2.0	Operational	Trial Run
79.	S. kannanur TP				
80.	Vallam TP	2.35	1.0	Operational	Trial Run
81.	Perundurai TP	3.14	1.0	Operational	Trial Run
82.	Melachokanathapuram TP	2.0	1.0	Operational	Trial Run
	Total (10 Nos)	26.67	12.1		
	Grand Total (82 Nos.)	1765.98	951.59		

Details of existing FSTPS in Tamil Nadu

S.No.	Location	Existing STP Capacity MLD	Capacity Being Utilized MLD	Operational Status of STP	Compliance Status of STP
	DMA				
1	Kangeyam	0.02	0.02	Operation	Complied
2	Kovilpatti	0.04	0.04	Operation	Complied
3	Tirumangalam	0.04	0.04	Operation	Complied
4	Dharapuram	0.03	0.03	Operation	Complied
5	Sengottai	0.02	0.02	Operation	Complied
6	Thuraiyur	0.02	0.02	Operation	Complied
7	Vickramasingapuram	0.03	0.03	Operation	Complied
8	Edappadi	0.03	0.03	Operation	Complied
9	Kadayanallur	0.04	0.04	Operation	Complied
10	Pattukottai	0.03	0.03	Operation	Complied
11	Tiruchengode	0.04	0.04	Operation	Complied
12	Melur	0.02	0.02	Operation	Complied
13	Ambasamuduram	0.03	0.03	Operation	Complied
14	Mannargudi	0.03	0.03	Operation	Complied
15	Aruppukottai	0.04	0.04	Operation	Complied
16	Sankarankoil	0.03	0.03	Operation	Complied
17	Vandavasi	0.02	0.02	Operation	Complied
18	Gudiyatham	0.03	0.03	Operation	Complied
19	Tenkasi	0.04	0.04	Operation	Complied
20	Paramakudi	0.04	0.04	Operation	Complied
	Total 20 FSTPs	0.62	0.62		
	CTP				
20.	Karunguzhi	0.024	0.024	Operation	Complied
21.	Periyanaikanpalayam	0.03	0.03	Operation	Complied
22.	Chengam TP	0.020	0.020	Operation	Trial run

23.	Alangayam TP	0.015	0.015	Operation	Trial run
24.	Mudukulathur	0.015	0.015	Operation	Trial run
	Total (5 Nos)	0.104	0.104		
	Grand Total (24Nos)	0.724	0.724		

Details of under construction STPs in Tamil Nadu

S.No.	Location	Capacity of the plant (MLD)	Physical Progress in %	Status of I&D or House sewer connection	Completion Timeline
CMWSSB					
1	Sholinganallur	54	90	Sep2022 (36 +18)18 MLD trial run work under progress	
2	Thiruvottriyur	31	100	Trial run Improvement& additional works in progress	
3	Kodungaiyur Zone - I	120	72.85		Aug 2022
4	Kodungaiyur Zone - II	120	86.63		Aug 2022
5	Nesapakkam Zone - IV	50	75.38		Aug 2022
6	Perungudi Zone - V	60	53.50		Aug 2022
7	Nesapakkam TTUF	10	97.05		June2022
8	Perungudi TTUF	10	70.0		Dec 2022
9	Chennai River Restoration Trust (CRRT),ChetpetMSTP	1	100.00		April 2022
10	CRRT, Nungambakkam MSTP	1.2	70.20		Aug 2022
11	CRRT, Langs Garden MSTP	10	46.0		Dec 2022
12	CRRT, Todd Hunter Nagar MSTP	0.4*4=1.6	84.0		July 2022
13	CRRT, Kotturpuram MSTP	0.3*2=0.6	99.0		June 2022
Total (13 Nos.)		469.40			
DMA					
14	Ambur	16.71	27		March -23
15	Coimbatore - Nanjudapuram	40.0	97	-	July -22
16	Coimbatore – Kuruchi&kuniyamuthur	30.53	99	-	July-22
17	Karaikudi	16.0	92	-	July -22
18	Nagercoil	17.66	92	-	Aug-22
19	Rajapalayam	21.85	85	-	Aug-22
20	Rameshwaram	4.08	42	-	March-23(Work Stopped due to court case)
21	Sattur	4.65	98	-	July-22
22	Tiruppur(Expansion of existing)	15.0	77		Aug-22
23	Tiruppur(Sarkarperipalayam)	36.0	95		July-22
24	Tiruppur(Chinnandipalayam)	20.0	95	-	July-22

25	Vellore	50.0	82	-	Jan-23
26	Ponneri	6.52	16		Oct-22
27	Tindivanam	11.44	Preliminary work is under progress		Dec-23
28	Villupuram Added Area	4.56			Dec-23
29	Pammal&Anagaputhur	27.0			Mar-23
30	Tiruchirapalli-STP-1	30.0	52	-	Desilting & Deepening of ponds, bund trimming work completed & now the work was stopped from 19.05.2021. It is proposed to integrated STP of 100 MLD with technology to meet TNPCB norms.
31	Tiruchirapalli-STP-2	37.0	88	-	Nov -22
Total 18		389.0			
CTP					
32	Sriperumbudur TP	8.50	90	5100/6000	31.07.2023
33	Thiruporur TP	4.02	90	3936/4479	30.09.2022
Total (2Nos)		12.52			
Grand Total (33 Nos)		870.92			

Details of under construction FSTPs in Tamil Nadu

Sl.No.	Location	Capacity of the plant (MLD)	Physical Progress in %	Completion Timeline
	DMA			
1	Koothanallur	0.02	87	June -22
2	Kulithalai	0.02	80	Sep -22
3	Padmanabhapuram	0.02	71	Jul -22
4	Virudhachalam	0.04	75	Aug - 22
5	Sirkali	0.02	80	Jun -22
6	Srivilliputhur	0.03	95	Jun -22
7	Vedaranyam	0.02	60	Jun -22
8	Cumbum	0.04	85	Jun -22
9	Aranthangi	0.02	60	Jul -22
10	Thiruthuraiipoondi	0.01	90	Jun -22
11	Pulianudi	0.04	70	Jun -22
12	Chengalpattu	0.02	75	Aug-22
13	Attur	0.04	60	Aug-22
14	Walajapet	0.03	34	Aug-22
15	Sivakasi	0.04	20	Sep -22
16	Keelakarai	0.02	42	Aug-22
17	Gudalur	0.02	43	Aug-22
18	Coonoor	0.01	43	Aug-22
19	Jayamkondan	0.02	40	Aug - 22
20	Vaniyambadi	0.03	2	Dec – 22
21	Kuzhithurai	0.04	20	Dec - 22
Total 21		0.55		
CTP				
22	Jalakandapuram TP	0.015	98	30.06.2022

23	Pennagaram TP	0.015	95	30.06.2022
24	Kaveripattinam TP	0.015	95	30.06.2022
25	Kurumbalur TP	0.010	87	30.06.2022
26	Pennadam TP	0.010	80	30.06.2022
	Total (5 Nos)	0.065		
	Grand Total (26Nos)	0.615		

Details of proposed STPs in Tamil Nadu State

Sl. No.	Locations	Capacity of the STP proposed - MLD	Status of Project (at DPR Stage/ Under tendering/ work to be awarded)	
	DMA			
1	Trichirapalli	7.50	Retender stage	
2	Tirunelveli	10.0		
3	Musiri		upgraded as Municipality from Town Panchayat- DPR Stage	
4	PunjaiPugalur			
5	Mangadu		DPR Stage yet to be finalized	
6	Chitlapakkam		Merged with Tambaram corporation. DPR preparations initiated.	
7	Madampakkam			
8	Peerkanakaranai			
9	Perungalathur			
10	Thiruneermalai			
	Total (10 Nos.)	17.5		
	CTP		Status of Project	Remarks
11	Sirugamani TP		DPR Stage	DPR is under preparation by WAPCOS / PWD.
12	Mohanur TP		DPR Stage	
13	Velur TP		DPR Stage	
14	Bhavani sagar TP		DPR Stage	
15	Sirumugai TP		DPR Stage	
16	Madathukulam TP		DPR Stage	
17	Omalur TP		DPR Stage	
18	Poolampatty TP		DPR Stage	
19	Kuthalam TP		DPR Stage	
20	Thirukattupalli TP		DPR Stage	
21	Thiruvaiyaru TP		DPR Stage	
22	Pethanaickenpalayam TP		DPR Completed	Final DPR received on 15.02.2022. DPR is under scrutiny.
23	Yethapur TP		DPR Stage	
24	Belur TP		DPR Stage	
25	Srivaikundam TP		DPR Stage	
26	Authoor TP		DPR Stage	

27	Eral TP		DPR Stage	
28	Alwarthirunagari TP		DPR Stage	
29	Then Thiruperaai TP		DPR Stage	
30	Arumuganeri TP		DPR Stage	
31	Mukkudal TP		DPR Stage	The SBM 2.0 2 nd State High Powered Committee meeting held on 26.02.2022 has approved to establish Decentralised STP & DEWATS method. Administrative sanction issued on 21.03.2022 and works are in various stages.
32	Gopalamudram TP		DPR Stage	
33	Kallidaikurichi TP		DPR Stage	
34	Cheranmahadevi TP		DPR Stage	
35	Veeravanallur TP		DPR Stage	
36	Patthamadai TP		DPR Stage	
37	Mela Seval TP		DPR Stage	
38	Naranammalpuram TP		DPR Stage	
	Total (28Nos)			
	Grand Total 38 Nos			

Details of Proposed FSTPs in Tamil Nadu

Sl.No.	Location	Capacity of the plant (MLD)	Physical Progress in %	Completion Timeline
	DMA			
1	Colachel	0.04	-	Work is to be Commissioned
2	Manaparai	0.02	-	
3	Nellikuppam	0.02	-	
4	Panruti	0.03	-	
5	Usilampatti	0.02	-	Administrative Sanction
	Total (5)	0.13		

Note : FSTPs at Vaniyambadi, Jayamkondan & Kuzhithurai are moved to under construction.

IV. Details of Industrial Pollution-TNPCB

Sl. No.	Details of Industries	State	PRS
1.	No. of industries in the State:	49,524	7,381
2.	No. of water polluting industries in the State:	11,538	1,770
3.	Quantity of effluent generated from the industries in MLD:	2,835.7	452.7
4.	Quantity of Hazardous Sludge generated from the Industries.	9,64,810 T/A	-
5.	No. of industrial units having ETPs:	11,538	1,770
6.	No. of industrial units connected to CETP:	1,497	Nil
7.	No. and total capacity of ETPs (details of existing/ under construction / proposed)	-	-
8.	Compliance status of the ETPs:	11,538 Industrial units provided zero liquid discharge system and there is no discharge into the water bodies	

9.	Number and total capacity of CETPs (details of existing/ under construction / proposed)	Existing – 36 Nos. (87.35 MLD). 35 CETPs in operation:1 No is closed.	Proposed – 10 Nos., Capacity 41 MLD. Note: No member unit is in operation without ZLD system.
		Under Construction 1 CETP at Kanchipuram (members 76 Nos.)-3650 KLD capacity.	
10	Status of compliance and operation of the CETPs	Details furnished below	

Status of compliance and operation of the CETPs in the State-TNPCB

Sl. No.	Location	No. of CETPs	No. of industrial units connected to CETP.	Restricted Quantity for CETPs (KLD)	Status of CETPs	Compliance Status TNPCB Norms.
1	Trichy	1	7	201.4	Operation	Complied
2	Dindigul	1	49	1517	Operation	Complied
3	Perundurai	1	14	1000	Operation	Complied
4	Ambur	1	49	1150	Operation	Complied
5	Ambur	1	17	330	Operation	Complied
6	Peranambut	1	36	600	Operation	Complied
7	Vanitech(P)Ltd	1	110	2000	Operation	Complied
8	Ranipet	1	82	3600	Operation	Complied
9	Ranipet	1	88	1875	Operation	Complied
10	Ranipet	1	20	700	Operation	Complied
11	Melvisharam	1	36	600	Operation	Complied
12	Madhavaram	1	14	400	Operation	Complied
13	Pallavaram	1	144	3000	Operation	Complied
14	Sivagangai	1	48	49.6	Operation	Not Complied
15	Ambattur	1	211	200	Operation	Complied
16	Tiruppur	1	75	7000	Operation	Complied
17	Tiruppur	1	6	180	Operation	Complied
18	Tiruppur	1	29	3555	Operation	Complied
19	Tiruppur	1	12	3520	Operation	Complied
20	Tiruppur	1	18	2750	Operation	Complied
21	Tiruppur	1	60	4785	Operation	Complied
22	Tiruppur	1	28	3748	Operation	Complied
23	Tiruppur	1	69	10758	Operation	Complied
24	Tiruppur	1	4	2250	Operation	Complied
25	Tiruppur	1	17	4950	Operation	Complied
26	Tiruppur	1	23	4500	Operation	Complied
27	Tiruppur	1	12	2700	Operation	Complied
28	Tiruppur	1	8	165	Operation	Complied
29	Tiruppur	1	15	2750	Operation	Complied
30	Tiruppur	1	15	2485	Operation	Complied
31	Tiruppur	1	19	4500	Operation	Complied
32	Tiruppur	1	25	3150	Operation	Complied
33	Tiruppur	1	9	1350	Operation	Complied
34	Perundurai	1	14	2681	Operation	Complied

35	Kanchipuram	1	62	1500	Under closure	Not Complied
36	Kodaikanal	1	40	850	Operation	Complied
Total		36	1497	87350		

Note:

1. The CETP, **Kanchipuram** was closed by the TNPCB and the power supply was disconnected on 01.07.2019, as the CETPs not implemented ZLD. The member units were also closed and power supplies disconnected. Hence, the member units are not in operation.
2. Directions issued to Sivagangai CETP to provide OCEMS by the TNPCB. The CETP has obtained stay order from the Hon'ble High Court of Madras (Madurai Bench) and the CETP is in operation.

Details of CETPs proposed in the State

Sl. No.	Location	Name of CETPs	CETP Capacity (MLD)	Status
1.	Perundurai	Sree Bhavani Dyeing Cluster Development Limited, Perundurai Taluk, Erode District.	4	1.The Secretary, Ministry of Textiles, GOI, New Delhi addressed vide letter No. 16.06.2021 to the Chief Secretary, Government of Tamil Nadu wherein it has been stated that the funding pattern to the CETPs is under revision for next five years.
2.	Perundurai	Kadayampatti CETP Private Limited, Bhavani, Perundurai Taluk, Erode District	6.25	
3.	Perundurai	Kadayampatti Common Reject Management Systems Private Limited (CRMS), Perundurai Taluk, Erode District	1.75	
4.	Erode	Gangapuram CETP Private Limited, Erode Taluk & District	4.5	
5.	Erode	Villarasampatti CETP Private Limited, Erode Taluk & District	4.5	
6.	Erode	M/s.Suriyampalayam CETP Private Limited, Erode	4.2	
7.	Erode	M/s. Green Kalingarayan CETP Private Limited, Erode	5.8	
8.	Erode	M/s. Erode CETP Private Limited (CRMS), Erode.	2.0	
9	Kumarapalayam	M/s. Kumarapalayam Green Cauvery Dyeing Cluster, Kumarapalayam	5.0	
10	Kumarapalayam	M/s. Green Environmental Association, Pallipalayam & Kumarapalayam, Namakal dist.	3.0	2. No member unit is in operation without ZLD system; Other member units are proposed industries only, ie. Green sites only.
TOTAL - 10 CETPs			41	

V. Solid Waste Management:

No	Solid Waste Management	State	PRS
1.	Total number of Urban Local Bodies	629	48
2.	Current Municipal Solid Waste Generation (TPD)	ULB- 15,003 Note: The MSW of RLB is furnished separately in the dossier below.	ULB- 1786.8
3.	a. Number of facilities b. Installed capacity –TPD c. Utilization of existing MSW processing facilities in TPD (bifurcated by type of processing eg- Waste to Energy (Tonnage and Power Output), Compost Plants (Windrow, Vermi, decentralized pit composting), bio-methanation, MRF, etc	*3676(DMA-2016 +CTP-1219+GCC-441) *9580 (DMA-6169+CTP-1448+GCC-1963) 7927 (DMA-5372 +CTP-1448+GCC-1107)	446 1489 1294
4.	Action plan to bridge gap between Installed Capacity and Current Utilization of processing facilities (if Gap > 20%)	1. It is proposed to increase the segregation, collection and treatment of MSWs. 2. The non-bio-gradable waste such as plastic wastes, etc. will be segregated and disposed scientifically. 3. Continuous awareness being created for source segregation and fixing target to achieve goal and periodically reviewed.	
5.	No. and capacity of C&D waste processing plants in TPD (existing, proposed and under construction)	Existing -2 Nos. of 400 TPD (each) Proposed – 3 Nos. at Coimbatore, Trichy and Madurai.	Nil
6.	Total No. of wards (ULBs) No. of wards having door to door collection service, No. of wards practicing segregation at source	12,997 12,518 11,428	1182 1161 1051
7	Details of MSW treatment facilities proposed and under construction (No., capacity, and technology)	Proposed -10 Nos. (DMA-10). Capacity :36.5 TPD (DMA-36.5)	1 No. 14 TPD

		Under Construction- *110 Nos. (DMA-98+ CTP- 3+GCC-9), Capacity 1532 TPD (DMA-871+GCC-645, CTP-16) 7 incinerator plants of 35 TPD & 9 pyrolysis plants of 0.9 TPD are completed and are in trial run. (Technology: Windrow composting, Vermi composting, Bio-gas production, Incineration, Pyrolysis, Micro composting, Organic Compositing, Resource Recovery)	15 Nos, 298 TPD
	Note* As the No. of Existing MSW facilities and capacity are increased the Under Construction facilities are reduced.		
8.	No. and area (in acres) of uncontrolled garbage dumpsites and Sanitary Landfills.	Uncontrolled garbage dumpsite - Nil. Sanitary land fill – Nil Bio-mining : Total quantity of Legacy waste generated 1,24,79,392 Cum. Total quantity of Legacy Waste biominced upto the month of May 2022 is 72,99,768 Cum (except in 58 ULBs, 100% biomining (26,31,587Cum) has been completed).	
9.	No. and area (in acres) of legacy waste within 1km buffer of both side of the rivers	Nil	
10.	No. of drains falling into rivers and No. of drains having floating racks/screens installed to prevent solid waste from falling into the rivers	29 MSW drains fall into water bodies.	

Rural Development and Panchayat Raj (RD & PR)

No.	Solid Waste Management	State	PRS
1.	Current Municipal Solid Waste Generation TPD	1272	8.30
2.	Number of Village Panchayats	12525	31
M	Details of MSW treatment facilities	321	1
3.	proposed (Nos)		

Status of ULB wise Management of Solid Waste-DMA, CTP& Greater Chennai Corporation (GCC)

ULBs	Total MSW generation (TPD)	Total MSW processed (TPD)	Existing MSW Facilities	Utilization Capacity of MSW facilities (TPD)	Proposed MSW Facilities & Completion timeline
DMA	7518	6169	Windrow/Vermi composting, Biogas generation	5372	100 Nos. of MSW treatment facilities are under construction & 10 Nos. of facilities are proposed.
CTP	1805	1573	Incineration, Pyrolysis, biocomposting,	1573	2 Incinerators & 1 Pyrolysis are under progress for processing non-recyclable dry waste on cluster basis.
GCC	5680	1107	Windrow/Vermi composting, Bio-gas generation	1107	9 Nos. of MSW treatment facilities are under construction.
Total	15003	8849		8052	

VI. Bio-medical Waste Management (BWM):

S.N	BWM	State	PRS
1.	Total Bio-medical generation (TPD)	88.134 T/Day	9.88 T/Day
2.	No. of Hospitals and Health Care Facilities:	27,361	6160
3.	Status of Treatment Facility/ CBMWTF:	Total -12 Nos. 10- Facilities under operation, 2-Facilities - Issued Closure order by TNPCB for non-compliance. 3 Nos Common facilities (CBMWTFs) are under establishment in Hosur, Gummidipoondi, & Tiruppur.	

VII. Hazardous Waste Management (HWM)

S.No	Hazardous Waste Management	Tamil Nadu State
1.	Total Hazardous Waste generation	Total : 9.64810 lakhs T/A Recyclable : 1.2081 lakhs T/A Utilizable : 7.30 lakhs T/A Land fillable : 0.90 lakhs T/A Incinerable : 0.24 lakhs T/A
2.	No. of Industries generating HW	4,199 units
3.	Treatment Capacity of	<u>2 Nos. of M/s Tamil Nadu Waste Management Limited</u>

	all TSDFs	<u>(TNWML) Facility :</u> a. <u>TSDF Gummidipoondi</u> : Permitted land fillable hazardous waste in SLF- 1,00,000 T/A Permitted for Incineration of hazardous waste with incinerator of capacity-1.5 T/Hr. b. <u>TSDF Viruthunagar</u> : Permitted land fillable hazardous waste in SLF-2,40,000 T/A
4.	Average Quantity of Hazardous waste reaching the TSDFs and treated	Land fillable hazardous waste- 90,296 T/A Incinerable hazardous waste- 7312 T/A
5.	Details of on-going or proposed TSDF	A common TSDF is proposed by TNWML (Unit-3) at Balethottam village, Pochampalli Taluk, Krishnagiri District for which CTE is granted under Water & Air Acts for direct landfillable Hazardous waste -83 TPD & treated landfillable hazardous waste -166 TPD.

VIII. Plastic Waste Management

Plastic Waste Management	STATE	PRS
Total Plastic Waste generation (TPD)	1077	109.2
Treatment/ Measures adopted for reduction or management of plastic waste	Recyclable/ Saleable plastics are sold to authorized vendors. Non-saleable plastics are sent to cement factories for co-incineration and also used as a component for laying roads. Incinerators & pyrolysis plants are under progress for processing non-recyclable dry waste in cluster basis. A plastic Shredding unit is available at each district under SWM Scheme. All the ULBs are enforcing Source segregation of wastes and the saleable fraction of plastic wastes are sold to recyclers and remuneration is paid back to sanitary workers. Apart from that, a total quantity of 1110 MT of single use plastics had been seized and a penalty of Rs.5.48 crore has been levied. The seized plastics are stored at Resource Recovery Centers (RRC) and disposed to Cement industries. The Government of Tamil Nadu has banned the single use plastics. The Government of Tamil Nadu has issued orders vide G.O (MS)No 116 Environment Climate Change and Forests Department, to use cloth bags instead of plastic carry bags.	

- IX.** Details of Alternate Treatment Technology being adopted by the State/UT: Nil
- X.** Identification of polluting sources including drains contributing to river pollution and action as per NGT order on in-situ treatment:

Total out falls in Six Polluted River Stretches			
Sl.No.	Name of the river	Total No of Out falls.	Remarks
1	Sarabanga	28	STPs / FSTPs are under construction. To bridge the gap STPs / FSTPs proposals are evolved.
2	Vasista	5	
3	Cauvery	39	
4	Thirumanimutharu	7	
5	Bhavani	40	
6	Tamirabarani	20	
	Grand Total	139	

Note : No MSW is discharged into the Polluted River Stretches.

XI. Details of Nodal Officer appointed by Chief Secretary in the State/UT: Nodal officers have been nominated vide G.O.Ms No.64 Environment and Forests (EC.2) Department dated 03.10.2020 by the Government of Tamil Nadu.

XII.Details of meetings carried under the Chairmanship Chief of Secretary in the State/UT: Environment Monitoring Cell meeting has been conducted by the Additional Chief Secretary to Government of Tamil Nadu, Environment and Forests Department, on 23.12.2020. The Chief Secretary to Government of Tamil Nadu has reviewed the progress on 20.04.2022.

XIII. Latest water quality of polluted river, its tributaries, drains with flow details and ground water quality in the catchment of polluted river.

Latest water quality of the polluted river stretches for the month of May 2022

Sl.No.	Name of the River	No of Monitoring Locations	BOD mg/l
1	Sarabanga	1	*
2	Thirumanimutharu	1	13.6
3	Vasista	1	*
4	Cauvery	19	<2-2.6

5	Bhavani	7	<2
6	Thamirabarani	12	<2-2.8
*Note : Samples not received.			

Source: TNPCB

Ground water quality in the catchment of polluted rivers-PWD

Name of the River	Ground water quality
Sarabanga	The State Ground and Surface Water Resources Data Centre (SG&SWRDC) has provided monitoring wells for observation of ground water quality in Danishpet, Omalur, Idaipadi, Thevur and Tharamangalam areas. The Total Dissolved Solids (TDS) of this stretch is found to be vary between 399 mg/l to 1885 mg/l . Danishpet is having TDS of good quality whereas the rest of the places having TDS value in the range of moderate quality.
Thirumanimuth- aru	The SG&SWRDC provided monitoring wells in Salem, Attayampatti and Palapatti areas. The TDS in this stretch vary between 500 mg/l to 2000 mg/l.
Vasista	The SG&SWRDC is having monitoring wells in Papanackennpatti, Yethapur, Athur and Thalaivasal. The TDS value is between 336 mg/l to 1029 mg/l
Cauvery	The SG&SWRDC is having ground water quality data for the areas of Dharmapuri, Mettur, Bhavani, Salem, Paramathivelur, Kumarapalayam, Karur, Erode, Musiri, Trichy, Kulithalai, Kumbakonam and Mayiladuthurai and in Dharmapuri the TDS varies between 523 mg/l to 2096 mg/l, at Salem the water quality varies between 412 to 2845 mg/l, at Namakkal the TDS exceed even 6000 mg/l. At Thanjavur and Cuddalore in most of the locations the water quality is found to vary between good and moderate and at few places of Cuddalore TDS varies between 5000 to 6000 mg/l
Bhavani	The general distribution of ground water quality varies between Good to moderate level. Especially Nilgiris is having good quality water.
Thamirabarani	The collected water quality data of Cheranmadevi, Thiruvudaimaruthur, Ambasamudram, Thirunelveli, Palayamkottai, and Ariyanaygipuram showed good, poor and moderate quality based on TDS.

XIV. Ground water regulation-PWD

Name of the River	Ground water regulation
Sarabanga	For effective management of Ground Water, 683 packaged drinking water firms operated illegally have been closed as per Honorable Madras High Court order passed under WP No.16299 / 2018. In the Tamirabarani basin, 9 illegally operating firms have been sealed and closed.
Thirumanimutharu	
Vasista	
Cauvery	
Bhavani	A Comprehensive Groundwater (Management and Development) Act, to regulate and manage the extraction of Groundwater is under active consideration of the Government of Tamil Nadu.
Thamirabarani	

XV. Good irrigation practices being adopted by the State-PWD:

Name of the River	Good irrigation practices being adopted by the State
Sarabanga	Awareness meetings are conducted under TNIAMP, ADB & State Funds. In some parts of the reach DRIP irrigation is practiced.
Thirumanimutharu	
Vasista	
Cauvery	
Bhavani	
Thamirabarani	Village level awareness campaigns are conducted periodically by PWD officials to adopt the crop rotation for good irrigation practices. Rehabilitation and modernization of Tanks, Anicuts and Supply channels are being carried out in TNIAMP projectas per GO Ms No: 140 PW (WR 1) Dept Dt: 21.06.2017 for an amount of Rs.107.09 crores.Kudimaramath woks as per G.O (Ms).No.98PW(W1)Dept/Dt: 22.04.2020 for an amount of Rs. 16.365 Crores is carried out in Tirunelveli and Thoothukudi Districts.

XVI. Rain Water Harvesting-PWD

Name of the River	Existing Structures (Nos)	Ongoing Works (Nos)	Proposed Works (Nos)
Sarabanga	5	2	10-Recharge Wells
Thirumanimutharu	6	--	14-Recharge Wells
Vasista	16	--	--
Cauvery	44	10	29
Bhavani	28	4-Check dams 15 - Recharge shafts	--

Thamirabarani	7	4	Total - 230 works. Barrages 3 Nos.—Rs.230 Crores. Artificial Recharge well 221 Nos, Recharge shaft 4 Nos. -Rs. 88.496Crores.
Total	106	35	283

XVII. Demarcation of Flood plain and removal of illegal encroachments - PWD:

Name of the River	Demarcation of Floodplain and removal of illegal encroachments
Sarabanga	Drone Survey completed by WAPCOS in January 2021. The draft DPR at a cost of Rs.2.0 Cr prepared by WAPCOS for identification of flood plain zones and area for afforestation to maintain Bio Diversity has been submitted and is under the scrutiny of PWD. Encroachment if any is identified in the survey will be evicted and other management works will be completed by May 2022 after rehabilitation and resettlement.
Thirumanimutharu	
Vasista	No Flood plains zones/encroachment have been identified.
Cauvery	Drone Survey completed by WAPCOS in January 2021. The draft DPR at a cost of Rs.20.0 Cr prepared by WAPCOS for identification of flood plain zones and area for afforestation to maintain Bio Diversity has been submitted and is under the scrutiny of PWD. Encroachment if any is identified in the survey will be evicted and other management works will be completed by May 2022 after rehabilitation and resettlement.
Bhavani	a. Drone Survey completed by WAPCOS in January 2021. The draft DPR at a cost of Rs. 2.0 Cr prepared by WAPCOS for identification of flood plain zones and area for afforestation to maintain Bio Diversity has been submitted and is under the scrutiny of PWD. b. 55 Nos of encroachments are to be removed belong to fishing community. Recommendations for alternate land has been sent to Secretary to Government, Revenue department by Commissioner for Revenue administration vide letter No F.2/41632/2005/Dt.15.2.2006.
Thamirabarani	a. To prepare comprehensive flood protection plan for Thamirabarani RiverRs. 4.00 Lakhs has been allotted vide GO Ms. No. 37 Revenue (DMII) Department 9.02.2017. Estimate has been prepared for Rs. 4.00 Lakhs for the demarcation of Flood plain zone and steps are being taken for the protection and management of Flood plain Zones of Thamirabarani .

	b. In Tirunelveli Corporation, Prosopis Juliflora on the river stretches for a length of 10km from Vilagam to Naranammalpuram river bridge were removed at a cost of 140.00 lakhs vide GO(2D) No. 14 PW (P2) Dept Dated 8.03.2019 to restore the River course for a free flow of flood water. c. In River Banks of the Thamirabarani, the following encroachments were identified by Public works department. Eviction notices issued by Govt. <table><tr><th>Sl. No.</th><th>District</th><th>Encroach ment Nos.</th><th>Evicted Nos.</th><th>Balance to be evicted Nos.</th></tr><tr><td>1.</td><td>Tirunelveli</td><td>683</td><td>639</td><td>44</td></tr><tr><td>2.</td><td>Thoothukudi</td><td>1084</td><td>117</td><td>967</td></tr><tr><td></td><td>Total</td><td>1767</td><td>756</td><td>1011</td></tr></table>	Sl. No.	District	Encroach ment Nos.	Evicted Nos.	Balance to be evicted Nos.	1.	Tirunelveli	683	639	44	2.	Thoothukudi	1084	117	967		Total	1767	756	1011
Sl. No.	District	Encroach ment Nos.	Evicted Nos.	Balance to be evicted Nos.																	
1.	Tirunelveli	683	639	44																	
2.	Thoothukudi	1084	117	967																	
	Total	1767	756	1011																	

XVIII. Maintaining minimum e-flow of river-PWD:

Name of the River	Maintaining minimum e-flow of river
Sarabanga	This river is only a flood carrier. The sewage water enters in to the river in Edapaddi Municipality, Omalur Town Panchayat and Poolampatti Town Panchayat. The above treatment plants are proposed under NadanthaiVaazhi Cauvery for which a draft DPR has been prepared by M/s. WAPCOS, submitted and is under the scrutiny of PWD. E flow will be maintained in this river after completion sewage treatment plants by May 2022. The treated water will flow as environmental flow.
Thirumanimutharu	This river is only a flood carrier. The sewage water enters in to the river in Salem Corporation. Treatment plants have been proposed under NadanthaiVaazhi Cauvery for which a draft DPR has been prepared by M/s. WAPCOS, submitted and is under the scrutiny of PWD. E flow will be maintained in this river after completion of sewage treatment plants by May 2022, the treated water will flow as environmental flow.
Vasista	This river is only a flood carrier. But the sewage water enters in to the river in Attur and Narasingapuram Municipality. After completion of sewage treatment plants in the above locations, the treated water will flow as environment flow.
Cauvery	Mettur dam is opened for irrigation from June 12 th to January 28 th based on availability of water every year. It is opened for drinking purpose in the remaining days. Usually a monthly minimum average E flow of 0.10 TMC is

	maintained. The E flow is maintained for more than 8 months. During the month of May 2022 an E Flow of 0.261 TMC was maintained.
Bhavani	An E flow of 16,179cusecs (including Irrigation purpose) was maintained in the river Bhavani during the Month of May 2022.
Thamirabarani	An average of 353.75cusecs of water is released into the river in the month of May2022 to ensure minimum environmental flow.

XIX. Plantation activities along the rivers-PWD

Name of the River	Plantation activities along the Rivers
Sarabanga	DPR is prepared and under scrutiny by PWD for planting 32,400 Nos. of tree saplings.
Thirumanimutharu	DPR is prepared and under scrutiny by PWD for planting 42,000 Nos. of tree saplings.
Vasista	There is no proposal at present.
Cauvery	DPR is prepared and under scrutiny by PWD for planting 1,44,500 Nos. of tree saplings.
Bhavani	DPR is prepared and under scrutiny by PWD for planting 86,500 Nos. of tree saplings.
Thamirabarani	At present there is no proposal on plantation on the River Banks and investigation works are being taken to implement it by Forest Department.

XX. Development of biodiversity park - PWD

Name of the River	Development of Biodiversity park
Sarabanga	Drone Survey has been completed by M/s. WAPCOS in January 2021. A draft DPR prepared by M/s. WAPCOS has been submitted and the scrutinization of DPR is done and finalization of DPR will be completed by the end of this month.
Thirumanimutharu	
Vasista	There is no proposal at present.
Cauvery	Drone Survey has been completed by M/s.WAPCOS in January 2021. A draft DPR prepared by M/s.WAPCOS has been submitted and scrutinization of DPR is done and finalization of DPR will be completed by end of this month.
Bhavani	
Thamirabarani	At present there is no proposal on biodiversity parks on the encroached River stretches and investigation works are being taken to implement it. <u>Rejuvenation of River Thamirabarani :</u> A DPR for rejuvenation of River Thamirabarani and its tributaries have been prepared for Rs.1024 Crores by the environment wing of Water Resources Department and has been submitted to the Engineer in Chief and Chief Engineer (General). It is under perusal for onward submission to the Govt. of Tamil Nadu.

XXI. Reuse of Treated Water - DMA

The policy for promotion of use of Treated Waste Water is prepared with a vision to maximize the collection & treatment of sewage generated and reuse of treated waste water on a sustainable basis, thereby reducing dependency on fresh water resources. Further, the policy promotes use of treated waste water as an economic resource.

In this regard, Tamil Nadu Government has launched waste water reuse policy during December 2019. At present Memorandum of Understanding (MoU) has been executed between the ULB and the user agency for the re-use of secondary treated effluent water.

S. No.	Name of the ULB	Quantity (MLD)	Usage/ Purpose
1	Nagapattinam	2.0	M/s KVK Power for cooling purpose
2	Dindugul	5.0	To maintain the TDS level of Tanners for Agro- forestry.
3	Tirunelveli	24.0	Nanguneri Special Economic Zone (SEZ) for Industries
4	Perambalur	3.0	MRF Industrial use
5	Ramanathapuram	3.0	NTC Infra
6	Coimbatore	15.0	Agricultural use to farmers association
7	Pollachi	11.50	Agricultural use to farmers association
8	Chinnamannur	3.0	Agricultural use
9	Karur	7.0	Agricultural use
10	Arakkonam	7.0	MRF Industrial use
Total		80.5	

XXII. Model River being adopted by the State & Action Proposed for achieving the bathing quality standards: River Bhavani.

XXIII. Status of Preparation of Action Plan by the 14 Coastal States:

The Government of Tamil Nadu vide G.O. MS No.64 Environment and Forests (EC.2) Department dated 03.10.2020, instructed the Department of Environment for preparation of action plan for the coastal and marine pollution.

XXIV. Regulation of Mining Activities in the State/UT: --

XXV. Action against identified polluters, law violators and officers responsible for failure for vigorous monitoring:

Closure directions have been issued to CETP at Kanchipuram. The CETP and the member units are not in operation. The power supply to the CETP and the member units were disconnected.

Also, closure directions have been issued to CETP, Sivagangai by the Tamil Nadu Pollution Control Board. The CETP is in operation by getting stay order from Hon'ble High Court of Judicature, Madras (Madurai Bench).

**Gist of Report on the progress made on the Polluted River Stretches
Tamil Nadu State
Month: May 2022.**

Sl.. No.	Details of works	Action taken
1	Polluted River Stretches identified	Priority-I River Cauvery, Sarabanga river, Vasista river and Thirumanimutharu river; Priority - IV Bhavani river and Priority - V Tamiraparani river.
2	Sewage Generation	3938.29 MLD in Tamil Nadu.
3.a.	Existing STPs	There are 82 STPs in operation with treatment capacity of 1765.98 MLD and 25 FSTPs of 0.724 MLD capacity. In addition, 752 MLD of sewage is treated using alternate technologies.
b.	Under construction STPs	33 STPs (870.92 MLD capacity) and 26 FSTPs (0.615MLD capacity) are under construction and they are at various stages of implementation. Incremental increase of 0.93 to 7.14% has been achieved during May 2022 in the under construction projects of STPs and the details are furnished as annexure-1 .
c.	Proposed STPs:	38 STPs are proposed to fill the gap of treatment of sewage.
4 a.	Existing MSW treatment :	15003 TPD of solid waste is generated in the State with treatment capacity of 9580 TPD(annexure-2)
b	Under construction MSW Facilities:	110 MSW facilities are being constructed to a capacity of 1532 TPD .
c.	Proposed MSW Facilities	10 Nos. of facilities are proposed to a capacity of 36.50 TPD .
d	Bio -mining	Total quantity of Legacy waste generated- 1,24,79,392 Cum

		Total quantity of Legacy Waste biominced upto the month of May 2022 is 72,99,768 Cum (except in 58 ULBs in which 100% biomincing 26,31,587Cum has been completed).
5 a.	Existing CETPs	There are 36 CETPs existing in the State with a capacity of 87350 KLD . Out of the 36 CETPs, 35 CETPs are in operation, one CETP (Kanchipuram) has been closed for non-compliance of Board orders. Closure directions issued to Sivagangai CETP to provide OCEMS by the TNPCB. The CETP has obtained stay order from the Hon'ble High Court of Madras (Madurai bench).
b.	Proposed CETPs :	Along the polluted river stretches, 10 CETPs of 41 MLD are proposed for dyeing units and they are under proposal stage. The DPRs have been forwarded to the Ministry of Textiles, Govt. of India for 50% funding during 2017-2021 and the fund is awaited.
6.	Biomedical waste management	27,361 health care units in the State generate 88.134 TPD of biomedical wastes, for which 10 bio-medical waste treatment facilities are in operation.
7	Hazardous Waste Management	Total hazardous Waste generation is 9.64810 lakhs ton per annum . Out of which re-cyclable is 1.2081 lakhs ton/annum, utilizable is 7.30 lakhs ton/annum, land fillable is 0.9 lakhs ton/annum and incinerable is 0.24 lakhs tons/annum.
8	Coastal Management Plan:	As per the directions in the NGT order dated 22nd September 2020, 46 Nos. of stretches have been identified in 14 districts as polluted zones for which action plan is under preparation.

9	Water Quality in Polluted River Stretches May 2022 <table><tr><th>Sl. No.</th><th>Name of the River</th><th>No.of Monitoring Locations</th><th>BOD mg/l</th><th>Standards</th></tr><tr><td>1</td><td>Sarabanga</td><td>1</td><td>*</td><td rowspan="6">BOD < 3 mg/l</td></tr><tr><td>2</td><td>Thirumanimutharu</td><td>1</td><td>13.6</td></tr><tr><td>3</td><td>Vasista</td><td>1</td><td>*</td></tr><tr><td>4</td><td>Cauvery</td><td>19</td><td><2-2.6</td></tr><tr><td>5</td><td>Bhavani</td><td>7</td><td><2</td></tr><tr><td>6</td><td>Thamirabarani</td><td>12</td><td><2-2.8</td></tr><tr><td colspan="5">*Note samples not received</td></tr></table>	Sl. No.	Name of the River	No.of Monitoring Locations	BOD mg/l	Standards	1	Sarabanga	1	*	BOD < 3 mg/l	2	Thirumanimutharu	1	13.6	3	Vasista	1	*	4	Cauvery	19	<2-2.6	5	Bhavani	7	<2	6	Thamirabarani	12	<2-2.8	*Note samples not received				
Sl. No.	Name of the River	No.of Monitoring Locations	BOD mg/l	Standards																																
1	Sarabanga	1	*	BOD < 3 mg/l																																
2	Thirumanimutharu	1	13.6																																	
3	Vasista	1	*																																	
4	Cauvery	19	<2-2.6																																	
5	Bhavani	7	<2																																	
6	Thamirabarani	12	<2-2.8																																	
*Note samples not received																																				
	Reuse of treated water87.0 MLD of industrial effluent is treated and reused. 80.50 MLD of Sewage is treated and reused for agricultural and industrial purposes.																																			
11	Maintenance of ground and surface water quality – PWD a. Ground water quality: Along the polluted river stretches monitoring wells have been provided and the ground water is monitored. b. Ground water regulation: Ground water (Management and development) Act to regulate and manage the extraction of Ground water is under active consideration of the Government. c. Good irrigation practices adopted by the State: Village level awareness meetings are carried-out by the PWD to adopt crop rotation and good irrigation practices. Rehabilitation and modernization of tanks are carried-out by the PWD. d. Rain Water Harvesting: 106 existing RWH structures along the PRS are provided; 35 Nos. are under progress and283Nos. of recharging wells and check dams are proposed. e. Demarcation of flood plain zones and removal of encroachments: In the PRS for demarcation of flood plain zones and removal of encroachments drone surveys are proposed for which DPR is under preparation. f. E-flow: It will be maintained in the rivers of Sarabanga, Thirumanimutharu,Vasista after completion of STPs. In the rivers of Cauvery, Bhavani and Tamiraparani E- flow is being maintained.																																			

Annexure- 1
INCREMENTAL PROGRESS OF STPs UNDER CONSTRUCTION

Sl.No.	Location	Capacity (MLD)	% of Completion		Incremental Progress %
			April 22	May 22	
	CMWSSB				
	Kodungaiyur Zone - I	120	68.20	72.85	6.38
	Kodungaiyur Zone - II	120	83.10	86.63	4.07
	Nesapakkam Zone - IV	50	70.0	75.38	7.14
	Perungudi Zone - V	60	53.0	53.50	0.93
	Nesapakkam TTUF	10	95.0	97.05	2.11
	Perungudi TTUF	10	69.25	70.00	1.07
	CRRT, Nungambakkam MSTP	1.2	69.5	70.20	1.09
	CRRT, Langs Garden MSTP	10	45.0	46.00	2.17
	CRRT, Todd Hunter Nagar MSTP	0.4*4=1.6	78.0	84.00	7.14
	CRRT, Kottupuram MSTP	0.3*2=0.6	92.0	99.00	7.07

Annexure-2
INCREMENTAL PROGRESS OF MUNICIPAL SOLID WASTE MANAGEMENT-STATE (ULBS)

Sl. No	Details	Dec 2021	Jan 2022	Feb 2022	March 2022	April 2022	May 2022	Incremental increase (%) (April 2022to May 2022)
1	MSW generation (TPD)	14,292	13,746	13,547	14882	14882	15003	0.81
2	MSW treatment capacity (TPD)	9456	9140	9158	9654	9574	9580	0.06
3	MSW utilization (TPD)	7459	7187	7272	7887	7894	7927	0.42

Note: INCREMENTAL PROGRESS OF EXISTING STPs -- NIL

INCREMENTAL PROGRESS OF UNDER CONSTRUCCION FSTPs - NIL



DDLABS AEL <tnpcbprs@gmail.com>

MPR - May 2022 -reg

1 message

ENGINEER'S STPSOUTH <engrstpsouth@gmail.com>

Wed, Jun 22, 2022 at 4:50 PM

To: DDLABS AEL <tnpcbprs@gmail.com>, metrowaterjai@gmail.com

Sir,

Kindly find the enclosed document.

With Regards,
O/o EE STP South/Special Initiatives



CMWSSB Revised MPR Format - MAY 2022 fi.doc
118K

**Format for submission of Monthly Progress Report in the NGT Matter OA
No. 673 of 2018 (in compliance to NGT order dated 24.09.2020)**

For the State of Tamil Nadu (Chennai) in May 2022

Overall status of the State:

- I. Total Population: 74.38 Lakhs
- II. Estimated Sewage Generation (MLD): 680 (Max)

III. Details of Sewage Treatment Plant:

S.No.	Details of Sewage Treatment Plant	State	PRS
1	Existing no. of STPs and Treatment Capacity (in MLD)	745	
2	Capacity Utilization of existing STPs (in ML)	16302.33 (Avg – 532.64 MLD)	
3	MLD of sewage being treated through Alternate technology	-	
4	Gap in Treatment Capacity in MLD	Nil	
5	No. of Operational STPs	13	
6	No. of Complying STPs	13	
7	No. of Non-complying STPs	Nil	

Details of each existing STP in the State & PRS – May 2022.

No.	Location	Existing STP Capacity	Capacity Being Utilized	Operational Status of STP	Compliance Status of STP
1	Nesapakkam STP Zone - IV	23	15.35	Operational	Complied <u>Parameters Range</u> pH – 6.5 to 8.5 BOD - < 20 mg/l COD – ≤ 250 mg/l TSS - < 30 mg/l Faecal Coliform – 10000 MPN/100 ml
2	Koyambedu STP Zone - III	34	30.86	Operational	
3	Kodungaiyur STP Zone II	80	60.71	Operational	
4	Kodungaiyur STP Zone I	80	61.9	Operational	
5	Perungudi STP Zone - V	12	10.37	Operational	
6	Koyambedu STP Zone – III	60	-	Rehabilitation	

7	Kodungaiyur STP Zone I& II	110	86.75	Operational	
8	Nesapakkam STP Zone - IV	40	23.8	Operational	
9	Perungudi STP Zone - V	54	45.04	Operational	
10	Perungudi STP Zone – V	60	49.22	Operational	
11	Nesapakkam STP Zone - IV	54	51.42	Operational	
12	Koyambedu STP Zone – III	120	88.86	Operational	
13	Sholinganallur STP (phase I)	18	8.36	Operational	
Total		745	532.64		

Details of under construction STPs in the State& PRS

No.	Location	Capacity of the plant in MLD	Physical Progress in %	Status of I&D or House sewer connections	Completion Timeline
1	Sholinganallur STP (PHASE II)	54	90.00		Sep 2022 (36+18) 18MLD trial runwork under progress
2	Thiruvottriyur STP	31	100.00		Trial Run, Improvement and additional works in progress
3	Kodungaiyur STP Zone - I	120	72.85		Aug 2022
4	Kodungaiyur STP Zone - II	120	86.63		Aug 2022
5	Nesapakkam STP Zone - IV	50	75.38		Aug 2022
6	Perungudi STP Zone - V	60	53.50		Aug 2022
7	Nesapakkam TTUF	10	97.05		Jun 2022
8	Perungudi TTUF	10	70.00		Dec 2022
9	CRRT - Chetpet MSTP	1.0	100.00		April 2022
10	CRRT- Nungambakkam MSTP	1.2	70.20		Aug 2022
11	CRRT- Langs Garden MSTP	10	46.00		Dec 2022
12	CRRT - Todd Hunter Nagar MSTP	0.4*4=1.6	84.00		July 2022
13	CRRT -Kotturpuram MSTP	0.3*2=0.6	99.00		June 2022
Total		469.40			

Details of proposed STPs in the State & PRS

No.	Location	Capacity of the STP proposed in MLD	Status of Project (at DPR Stage/ Under Tendering/ Work to be Awarded)	Likely Date of Completion
Total				

Details of proposed STPs in the State

No.	Location	Capacity of the STP proposed in MLD	Status of Project (at DPR Stage/ Under Tendering/ Work to be Awarded)	Likely Date of Completion
Total				

IV. Details of Industrial Pollution:

- No. of industries in the State& PRS:
- No. of water polluting industries in the State& PRS:
- Quantity of effluent generated from the industries in MLD:
- Quantity of Hazardous Sludge generated from the Industries in TPD:
- Number of industrial units having ETPs in State & PRS:
- Number of industrial units connected to CETP:
- Number and total capacity of ETPs (details of existing/ under construction / proposed)
- Compliance status of the ETPs:
- Number and total capacity of CETPs (details of existing/ under construction / proposed)
- Status of compliance and operation of the CETPs

Town	No. of industries	Industrial discharge	Status of ETPs	Status of CETPs (existing, under construction & proposed)

V. Solid Waste Management:

- Total number of Urban Local Bodies and their Population
- Current Municipal Solid Waste Generation (**State & PRS**)

- Number, installed capacity and utilization of existing MSW processing facilities in TPD (bifurcated by type of processing e.g.- Waste to Energy (Tonnage and Power Output), Compost Plants (Windrow, Vermi, decentralized pit composting), bio methanation, MRF etc **(State & PRS)**
- Action plan to bridge gap between Installed Capacity and Current Utilization of processing facilities (if Gap > 20%) **(State & PRS)**
- No. and capacity of C&D waste processing plants in TPD (existing, proposed and under construction) **(State & PRS)**
- Total no. of wards, no. of wards having door to door collection service, no. of wards practicing segregation at source **(State & PRS)**
- Details of MSW treatment facilities proposed and under construction (no., capacity, and technology) **(State & PRS)**
- No. and area (in acres) of uncontrolled garbage dumpsites and Sanitary Landfills.
- No. and area (in acres) of legacy waste within 1km buffer of both side of the rivers
- No. of drains falling into rivers and no. of drains having floating racks/screens installed to prevent solid waste from falling into the rivers.

Status of ULB wise Management of Solid Waste

ULB	Total MSW generation in TPD	Total MSW being processed in TPD	Existing MSW facilities	Utilization Capacity of the existing MSW facilities	Proposed MSW Facilities & Completion Timeline
Total					

VI. Bio-medical Waste Management:

- Total Bio-medical generation (State & PRS):
- No. of Hospitals and Health Care Facilities:
- Status of Treatment Facility/ CBMWTF:

VII. Hazardous Waste Management:

- Total Hazardous Waste generation **(State & PRS):**

- No. of Industries generating Hazardous waste
- Treatment Capacity of all TSDFs
- Avg. Quantity of Hazardous waste reaching the TSDFs and Treated
- Details of on-going or proposed TSDF

VIII. Plastic Waste Management:

- Total Plastic Waste generation (State & PRS):
- Treatment/ Measures adopted for reduction or management of plastic waste:

IX. Details of Alternate Treatment Technology being adopted by the State/UT

X. Identification of polluting sources including drains contributing to river pollution and action as per NGT order on in situ treatment:

XI. Details of Nodal Officer appointed by Chief Secretary in the State/UT:

XII. Details of meetings carried under the Chairmanship Chief of Secretary in the State/UT:

XIII. Latest water quality of polluted river, its tributaries, drains with flow details and ground water quality in the catchment of polluted river;

XIV. Ground water regulation:

XV. Good irrigation practices being adopted by the State:

XVI. Rain Water Harvesting:

XVII. Demarcation of Floodplain and removal of illegal encroachments:

XVIII. Maintaining minimum e-flow of river:

XIX. Plantation activities along the rivers:

XX. Development of biodiversity park:

XXI. Reuse of Treated Water:

XXII. Model River being adopted by the State & Action Proposed for achieving the bathing quality standards:

XXIII. Status of Preparation of Action Plan by the 13 Coastal States:

XXIV. Regulation of Mining Activities in the State/UT:

XXV. Action against identified polluters, law violators and officers responsible for failure for vigorous monitoring



DDLABS AEL <tnpcbprs@gmail.com>

NGT 673 - April 2022 & May 2022

1 message

SE SWM <solidwastecorp5@gmail.com>
To: tnpbprs@gmail.com

Wed, Jun 8, 2022 at 1:19 PM

Sir/Madam

Please see the attached

Regards
SWM

2 attachments

 **NGT O.A No.673 April 2022 (1).pdf**
355K

 **NGT O.A No.673 May 2022 (1).pdf**
382K

	Details of MSW treatment facilities under construction (technology)	Incinerator, Bio CNG, and Pyrolysis Plant	
8	No. and area (in acres) of uncontrolled garbage dumpsites and Sanitary Landfills.	5nos / 494.16 acres	
9	No. and area (in acres) of legacy waste within 1km buffer of both side of the rivers	Nil	
10	No. of drains falling into rivers and no. of drains having floating racks/screens installed to prevent solid waste from falling into the rivers	272 (Storm water drains falling into rivers)	
	Status of ULB wise SWM		
	ULB	Greater Chennai Corporation (GCC)	
	Total MSW generated in TPD	5680	
	Total MSW processed in TPD	1107	
	Existing MSW facilities	MCC, Bio CNG, Bio Gas, Biomethanation, Windrow Compost, Horticulture Waste process, RRC MRF, Incinerator, Olfake, Baling machines	
	Utilization capacity of the existing MSW facilities	1107.00	
	Proposed MSW Facilities & Completion Timeline		
	Status of ULB/RLB wise SWM	Tamil Nadu State	
	ULB/RLB (No.),		
	Total MSW generated in TPD		
	Total MSW processed in TPD		
	Existing MSW facilities		
	Utilization capacity of the existing MSW facilities		
	Proposed MSW Facilities & Completion Timeline		
VIII	Plastic Waste Management:		
1	Total Plastic Waste generation: TPD	461	
2	Treatment/ Measures adopted for reduction or management of plastic waste:	RRC, MRF, Incinerator, Pyrolysis Plant, Olfake, Baling machines	
XXIV	Regulation of /Mining Activities in the State/UT		

2/8.6.22
Assistant Executive Engineer/SWM

P.K.h
8.6.2022
Executive Engineer/SWM

Legacy waste

TN ULBs	Location	legacy waste estimated (Cu.Mtr)	Under process (Balance Waste) Cu.Mtr						
			Upto Dec-2021	Jan-22	Feb-22	Mar-22	Apr-22	May-22	Remarks
Greater Chennai Corporation	Athipattu	107811	34159	28126	36183	8497	8064	36696	21689 cu.mtr of legacy waste added
	Sathangadu	125635	75911	68751	66813	64216	64005	63571	
	Perungudi	3428453	3021802	2890635	3164480	2962409	2787776	2598770	

NMCG Format for Submission of Monthly Progress Report in the NGT Matter
OA No.673 of 2018

(in compliance to NGT order dated 24.09.2020)

For the Month of May 2022 - Prepared By Greater Chennai Corporation

For the Month of May 2022 - Prepared By Greater Chennai Corporation					
V	Solid Waste Management:				
		Tamil Nadu State			
1	Total number of Urban Local Bodies and their Population	62.5 LAKHS			
2	Current Municipal Solid Waste Generation TPD	5680			
3	Existing MSW processing facilities	Total No.	Installed Capacity (TPD)	Utilization Capacity (TPD)	Remarks
a.	Windrow Compost	2	100	100	
b.	Vermi Compost	0	0	0	
c.	Decentralized pit composting	206	581	433	
d.	Biomethanation	6	21	18	
e.	MRF/RRC	186	468	234	
f.	Others: (Breakup) 1. Incinerators - 2 No (60 MTD) 2. Gardengarbage & Tender coconut shell processing plant - 4 locations (320 MTD) 3. Offtake of baled plastic to cement factories (300 MTD)	6	680	230	
g.	Waste to Energy 1. Bio-gas	34	13	7	
	2. Bio-CNG	1	100	85	
	Total	441	1963	1107	
4	Action plan to bridge gap between Installed Capacity and Current Utilization of processing facilities (if Gap > 20%)	Continuous awareness being created for source segregation and fixing target to achieve goal and periodically reviewed			
4a	No. and capacity of C&D waste processing plants in TPD	2 no (400 each)	800	519	
6	Total no. of wards	200			
	Total no. of wards having door to door collection service	200			
	Total no. of wards practicing segregation at source	200			
7a.	Details of MSW treatment facilities proposed (no.)	-			
	Details of MSW treatment facilities proposed (capacity, TPD)	-			
	Details of MSW treatment facilities proposed (technology)	-			
7b.	Details of MSW treatment facilities under construction (no.)	9			Bio-CNG 6nos -100 TPD each Pyrolysis 2nos -20TPD each Incinerator 1 no - 5TPD
	Details of MSW treatment facilities under construction (capacity, TPD)	645			



DDLABS AEL <tnpcbprs@gmail.com>

LWM PROGRESS SENT - REG

1 message

dma office <dmaoffice@gmail.com>
To: DDLABS AEL <tnpcbprs@gmail.com>

Wed, Jul 13, 2022 at 6:14 PM

Sir/Madam,
Please see the attachment.

2 attachments **FSTPs Progress _ State_ May month Progress.xls**
34K **LWM Status (May'22 Month).doc**
185K

Directorate of Municipal Administration

April'2022 month Progress Report in the NGT Matter OA No. 673 of 2018 (in compliance to NGT order dated 24.09.2020)

Overall status of the CMA:

- I.** Total Population : 1,66,51,347
- II.** Estimated Sewage Generation (MLD) : 1698.73 (State)
Estimated Sewage Generation (MLD): 375.61 (PRS)

III.Details of Sewage Treatment Plant:

S.No.	Details of Sewage Treatment Plant	State	PRS
1	Existing no. of STPs and Treatment Capacity (in MLD)	59 Nos & 994.31	14Nos & 273.52
2	Capacity Utilization of existing STPs	404.85	135.80
3	MLD of sewage being treated through Alternate technology	Nil	
4	Gap in Treatment Capacity in MLD	704.42	137.72
5	No. of Operational STPs	59 nos	14 nos
6	No. of Complying STPs	59 nos	14 nos
7	No. of Non-complying STPs	Nil	

Details of each existing STP in the State & PRS

S. No	Location	Existing Capacity of STP (in MLD)	Capacity being Utilized (in MLD)	Operational Status of STP	Compliance Status of STP
1	Coimbatore	70.00	35.00	Operational	Comply
		60.00	6.00	Operational	Comply
2	Vellore	10.28	8.00	Operational	Comply
3	Dindigul	13.65	3.00	Operational	Comply
4	Avadi	36.00	6.00	Operational	Comply
	Avadi	4.00	1.00	Operational	Comply
5	Madurai	125.00	24.00	Operational	Comply
5	Madurai	45.70	15.00	Operational	Comply
6	Thanjavur	28.05	14.15	Operational	Comply
7	Tiruppur	15.00	8.50	Operational	Comply
8	Cuddalore	12.25	6.70	Operational	Comply
9	Kanchipuram	14.70	14.70	Operational	Comply
10	Maraimalai Nagar	2.20	2.20	Operational	Comply
11	Pallavapuram	(CMWSSB STP 115@Perungudi)		Operational	Comply
12	Tiruvallur	6.20	5.50	Operational	Comply
13	Chidambaram	9.44	6.10	Operational	Comply
14	Thiruvannamalai	8.70	4.75	Operational	Comply
15	Viluppuram – (Kakuppam)	9.00	7.00	Operational	Comply
	Viluppuram (Erumanthangal)	3.50	1.80	Operational	Comply
16	Arakkonam	11.04	2.00	Operational	Comply
17	Thirupathur	11.43	3.00	Operational	Comply
18	Bodinayakkanur	12.08	4.00	Operational	Comply
19	Chinnamanur	3.99	3.72	Operational	Comply
20	Periyakulam	5.47	4.00	Operational	Comply
21	Ramanathpuram	7.00	5.80	Operational	Comply
22	Rasipuram	6.96	3.30	Operational	Comply

23	Theni-Allinagaram	12.05	9.50	Operational	Comply
24	Sivagangai	4.92	2.00	Operational	Comply
25	Dharmapuri	4.86	3.50	Operational	Comply
26	Karur	15.00	5.63	Operational	Comply
27	Krishnagiri	12.34	8.00	Operational	Comply
28	Namakkal	5.00	5.00	Operational	Comply
29	Nagapattinam STP-1	9.63	4.40	Operational	Comply
	Nagapattinam STP-2	2.69	1.10	Operational	Comply
30	Tiruvarur	6.92	4.10	Operational	Comply
31	Ariyalur	4.16	1.50	Operational	Comply
32	Pudukkottai	10.62	6.00	Operational	Comply
33	Perambalur	4.20	3.60	Operational	Comply
34	Udhagamandalam	5.00	4.00	Operational	Comply
35	Udumalaipet	7.81	4.00	Operational	Comply
36	Virudhunagar	7.65	3.80	Operational	Comply
37	Tambaram	30.00	3.00	Under trial run	Comply
38	Tuticorin	28.00	2.50	Under trial run	Comply
39	Tiruchendur	3.90	1.80	Operational	Comply
40	Ulundurpet	3.15	-	Under trial run	Comply
41	Pollachi	11.25	0.5	Under trial run	Comply
PRS (14 Nos)					
42	Tiruchirappalli	58.00	58.00	Operational	Comply
43	Salem - Vellakuttai STP	13.00	9.00	Operational	Comply
	Salem - Anaimeedu STP	6.00	5.00	Operational	Comply
	Salem - Mankuttai STP	35.00	4.00	Operational	Comply
	Salem - Vandipattai STP	44.00	1.00	Operational	Comply
44	Tirunelveli	24.20	10.00	Operational	Comply
45	Erode	50.55	27.00	Operational	Comply
46	Mettur STP-1	0.82	0.50	Operational	Comply
	Mettur STP-2	0.92	0.15	Operational	Comply

	Mettur STP-3	5.45	2.20	Operational	Comply
47	Kumbakonam	17.00	12.50	Operational	Comply
48	Mayiladuthurai	5.85	5.85	Operational	Comply
49	Sathiyamanagalam	4.08	0.50	Under trial run	Comply
50	Mettupalayam	8.65	-	Under trial run	Comply
Total	59 nos	994.31	404.85		

Details of under construction STPs in the State & PRS

S.No	Location	Capacity of the plant in MLD	Physical Progress in %	Status of I&D or House sewer connections	Completion Timeline
1	Ambur	16.71	27%	-	March-23
2	Coimbatore - Nanjudapuram	40.00	97%	-	July -22
	Coimbatore – Kuruchi & kuniyamuthur	30.53	99%		July -22
3	Karaikudi	16.00	92%	-	July -22
4	Nagercoil	17.66	92%	-	Aug -22
5	Rajapalayam	21.85	85%	-	Aug-22
6	Rameshwaram	4.08	42%	-	March-23 (Work stopped due to court case)
7	Sattur	4.65	98%	-	July -22
8	Tiruppur(Expansion of existing)	15.00	77%	-	Aug-22
	Tiruppur (Sarkarperiyapalayam)	36.00	95%	-	July-22
	Tiruppur (Chinnandipalayam)	20.00	95%	-	July-22
9	Vellore	50.00	82%	-	Jan-23
10	Ponneri	6.52	16%	-	Oct -22
11	Tindivanam	11.44	Preliminary work under progress		Dec-23
12	Villupuram Added Area	4.56			Dec-23
13	Pammal & Anagaputhur	27.00			March-23
PRS (2 Nos)					

14	Trichirapalli-STP1	30.00	52%	-	Desilting and Deepening of Ponds, Bund trimming work completed & now the work was stopped from 19.05.2021 It is proposed to integrated STP of 100MLD with technology to meet out latest TNPCB norms
	Trichirapalli-STP2	37.00	88%	-	Nov-22
Total (17 nos)		359.00			

In addition to above, 46 no. of FSTPs are taken up for implementation

- (i) Completed - 19 Nos
- (ii) Under construction – 22 Nos
- (iii) Work to be commenced – 1 Nos
- (iv) To be started – 3 Nos
- (v) AS Stage - 1 No.

In which 6 no of FSTPs falls under polluted river stretches (Cauvery- 1no, Vassista -1 no, Sarabanga – 1 no & Thamirabarani – 2 nos.)

X. Identification of polluting sources including drains contributing to river pollution and action as per NGT order on insitu treatment:

SI. No	Name of the River	Name of the ULB	No. of location joining into major canal/ river	Remarks
1	Cauvery	Komarapalayam	5	I&D Work DPR under preparation
2	Cauvery	Pallipalayam	7	
3	Cauvery	Kulithalai	3	
4	Cauvery	Bhavani	6	
5	Tamirabarani	Ambasamudram	6	
6	Tamirabarani	Vickaramasingapuram	12	I&D Work DPR under preparation
7	Vassista	Attur	3	
8	Vassista	Narasingapuram	3	
9	Sarabanga	Idappadi	22	

XXI. Reuse of Treated Water:

The policy for promotion of use of Treated Waste Water is prepared with a vision to maximise the collection & treatment of sewage generated and reuse of treated waste water on a sustainable basis, thereby reducing dependency on fresh water resources. Further, the policy promotes use of treated waste water as an economic resource.

In this regard, Tamil Nadu Government has launched waste water reuse policy on December 2019. At present Memorandum of Understanding (MoU) has been executed between the ULB and the user agency for the re-use of secondary treated effluent water (STEW).

S. No	Name of the ULB	Quantity (in MLD)	Usage/ Purpose
1	Nagapattinam	2.00	M/s KVK Power for cooling purpose
2	Dindugul	5.00	To maintain the TDS level of Tanners as well for Agro- forestry.
3	Tirunelveli	24.00	Nanguneri SEZ for Industries
4	Perambalur	3.00	MRF Industrial use
5	Ramanathapuram	3.00	NTC Infra
6	Coimbatore	15.00	Agricultural use to farmers association
7	Pollachi	11.50	Agricultural use to farmers association
8	Chinnamannur	3.00	Agricultural use
9	Karur	7.00	Agricultural use
10	Arakkonam	7.00	MRF Industrial use



DDLABS AEL <tnpcbprs@gmail.com>

DMA SWM Details -PRS MPR- May-2022

1 message

Swachh Bharat Mission <sbmpmucma@gmail.com>

Tue, Jul 19, 2022 at 11:13 AM

To: DDLABS AEL <tnpcbprs@gmail.com>

Cc: dma office <dmaoffice@gmail.com>

Dear Sir/Madam,
Please find attached Polluted River Stretch MPR format for the month of May-2022

Thanks & Regards
Project Management Unit
Office of State Mission Director
Swachh Bharat Mission (U) 2.0
Directorate of Municipal Administration
Chennai -28

5 attachments**1.SWM Revised MPR Format for 158 ULBs.docx**
21K**PRS ULBs -SWM Existing Facilites.xlsx**
18K**2. SWM-LWM MPR-excell sheet.xlsx**
16K**CMA ULBs-SWM Existing Facilites.xlsx**
40K**3. Gap anaylsis JS -Mail.xlsx**
26K

National Mission for Clean Ganga
Format for submission of Monthly Progress Report in the NGT Matter OA
No. 673 of 2018 (in compliance to NGT order dated 24.09.2020)

For the State of Tamil Nadu

I. Solid Waste Management: (For Polluted River Stretches ULBs)

- Total number of Urban Local Bodies and their Population: **158 ULBs & Population - 1,98,84,343**
- Current Municipal Solid Waste Generation: **7518 TPD & 1314 TPD**
- Number, installed capacity and utilization of existing MSW processing facilities in TPD (bifurcated by type of processing eg- Waste to Energy (Tonnage and Power Output), Compost Plants (Windrow, Vermi, decentralized pit composting), bimethanation, MRF etc : **Enclosed**
- Action plan to bridge gap between Installed Capacity and Current Utilization of processing facilities (if Gap > 20%) Nil
- No. and capacity of C&D waste processing plants in TPD (existing, proposed and under construction) : **5 ULBs and 325 TPD**
- Total no. of wards, no. of wards having door to door collection service, no. of wards practicing segregation at source : **Enclosed**
- Details of MSW treatment facilities proposed and under construction (no., capacity, and technology) : **Enclosed**
- No. and area (in acres) of uncontrolled garbage dumpsites and Sanitary Landfills. **Nil**
- No. and area (in acres) of legacy waste within 1km buffer of both side of the rivers- 1 no.(Erode) &19 acres – **Biomining Work completed**
- No. of drains falling into rivers and no. of drains having floating racks/screens installed to prevent solid waste from falling into the rivers – Nil.

NMCG Format for Submission of Monthly Progress Report in the NGT Matter OA No.673 of 2018							
(in compliance to NGT order dated 24.09.2020)							
	For the Month of May 2022 -Department	CMA					
V	Solid Waste Management:						
		Tamil Nadu State			Polluted River Stretches		
1	Total number of Urban Local Bodies and their Population	158 ULBs / 1,98,84,343			21 ULBs / 31,09,821		
2	Current Municipal Solid Waste Generation TPD	7518 TPD			1679 TPD		
3	Existing MSW processing facilities	Total No.	Installed Capacity (TPD)	Utilization Capacity (TPD)	Total No.	Installed Capacity (TPD)	Utilization Capacity (TPD)
a.	Windrow Compost	66	209	162	6	19	16
b.	Vermi Compost	27	115	90	4	5	3
c.	Decentralized pit composting	750	2881	2780	182	662	637
d.	Biomethanation	47	189	140	13	53	48
e.	MRF/RRC	235	1005	1005	32	136	136
f.	others	891	450	355	138	59	56
g.	Waste to Energy						
h.	Dry waste disposed to local vendors and Cement industries		1320	840		425	268
	Total	2016	6169	5372	375	1359	1164
4	Action plan to bridge gap between Installed Capacity and Current Utilization of processing facilities (if Gap > 20%)						
5	No. and capacity of C&D waste processing plants in TPD (existing, proposed and under construction)	Existing (No. & capacity)	Proposed (No. & Capacity)	Under construction (No. & Capacity)	Existing (No. & Capacity)	Proposed (No. & Capacity)	Under construction (No. & Capacity)
		-	Proposed in Coimbatore, Salem Trichy Madurai and Thoothukudi Corporations	-	-	Proposed in Trichy Corporation	-
6	Total no. of wards	5178			717		
	Total no. of wards having door to door collection service	5004			696		
	Total no. of wards practicing segregation at source	4371			633		
7a.	Details of MSW treatment facilities proposed (no.)	10 Nos			1 Nos		
	Details of MSW treatment facilities proposed (capacity, TPD)	36.5 TPD			14 TPD		
	Details of MSW treatment facilities proposed (technology)	Incineration for Dry waste and MCC for Wet waste			Incineration for Dry waste and MCC for Wet waste		
7b.	Details of MSW treatment facilities under construction (no.)	98 Nos			15 Nos		
	Details of MSW treatment facilities under construction (capacity, TPD)	871 TPD			298 TPD		

V	Solid Waste Management:		
		Tamil Nadu State	Polluted River Stretches
	Details of MSW treatment facilities under construction (technology)	Micro Composting Centre, Incineration and RRC and Onsite composting Centres	Micro Composting Centre, Incineration and RRC and Onsite composting Centres
8	No. and area (in acres) of uncontrolled garbage dumpsites and Sanitary Landfills.	Nil	Nil
9	No. and area (in acres) of legacy waste within 1km buffer of both side of the rivers	Nil	Nil
VIII	<u>Plastic Waste Management:</u>		
1	Total Plastic Waste generation:TPD	514	103
2	Treatment/ Measures adopted for reduction or management of plastic waste:	All the ULBs are enforcing Source segregation of waste through IEC activities by animators and the saleable fraction of plastic waste is sold to recyclers and remuneration is paid back to sanitary workers. Apart from that a total quantity of 1305.0 MT of single use plastics had been seized and a penalty of Rs.6.60 crores has been collected. The seized plastics are stored at Resource Recovery Centres (RRC) and disposed to Cement industries.	All the ULBs are enforcing Source segregation of waste through IEC activities by animators and the saleable fraction of plastic waste is sold to recyclers and remuneration is paid back to sanitary workers. Apart from that a total quantity of 183.27 MT of single use plastics had been seized and a penalty of Rs.1.66 crores has been collected. The seized plastics are stored at Resource Recovery Centres (RRC) and disposed to Cement industries.
XXIV	Regulation of /Mining Activities in the State/UT		



DDLABS AEL <tnpcbprs@gmail.com>

May MPR

1 message

Schemes Section <ctpschemes21@gmail.com>
To: tnpbprs@gmail.com

Mon, Jul 18, 2022 at 11:12 AM

--
Sir / Madam,

* Please see the attached file.*

Commissionerate of Town Panchayats,
7th & 8th Floor,
Urban Administrative Building,
Chennai - 600 028.

[image: logo]

"Go Green. Save Paper" *

*Print only if necessary & use both sides of Paper - this will preserve
trees on planet earth.*

2 attachments

MPR Format May (1) (1).docx
42K



May -Gap anaylsis (1).xlsx
25K

STPs under progress

TN ULBs	STP Name	Sanctioned month and year	capacity (MLD)	% of completion		
				Mar-22	Apr-22	May-22
	<u>STP</u>					
DTP	Sriperumbudur TP	19.6.2012/ 16.5.2014	8.50	86%	90%	90%
	Thiruporur TP	19.09.2013 / 11.01.2017	4.02	84.50%	84.50%	90%
	Ponneri TP	19.09.2013 / 29.12.2016	6.52	Upgrad ed as Munici pality	Upgrad ed as Munici pality	Upgrad ed as Munici pality
	Manachanallur TP	17.05.2017	6.41	100%	100%	100%
	S.Kannanur TP	19.09.2013 / 17.05.2017				
	Vallam TP	19.09.2013 / 11.01.2017	2.35	100%	100%	100%
	Perundurai TP	17.01.2013 / 15.05.2020	3.14	100%	100%	100%
	Melachokanathapuram TP	04.11.2019	2.00	100%	100%	100%
	<u>FSTP</u>					
DTP	Mudukulathur TP	21.1.2019	0.015	95%	100%	100%
	Jalakandapuram TP	21.1.2019	0.015	98%	98%	98%
	Pennagaram TP	21.1.2019	0.015	90%	95%	95%
	Kaveripattinam TP	21.1.2019	0.015	92%	95%	95%
	Chengam TP	21.1.2019	0.02	-	-	-
	Kurumbalur TP	21.1.2019	0.01	80%	85%	87%

	Pennadam TP	21.1.2019	0.01	80%	80%	80%
	Alangayam TP	21.1.2019	0.015	-	-	-

Liquid Waste Management

TN ULBs	sewage generation (in MLD)			Installed Treatment Capacity of STPs (in MLD)			Gap in Treatment capacity		
	Mar-22	Apr-22	May-22	Mar-22	Apr-22	May-22	Mar-22	Apr-22	May-22
DTP	429.29	429.29	429.29	26.760	26.760	26.760	402.530	402.530	402.530

Waste Treatment - Capacity Ut

TN ULBs	Installed treatment capacity			capacity utilisation %			Gap in capacity utilisation %		
	Mar-22	Apr-22	May-22	Mar-22	Apr-22	May-22	Mar-22	Apr-22	May-22
DTP	26.760	26.760	26.760	6.154	6.154	6.154	20.606	20.606	20.606

Solid Waste Management

[illegible]

Solid Waste Treatment -Capacity Utilisation

[illegible]

)
May-22
235

May-22
-

Legacy waste

TN ULBs	legacy waste estimated (Cu.Mtr)	Legacy waste 100% biominced (Cu.Mtr)		Under process (Balance Waste) Cu.Mtr					Remarks
		ULB	Waste	Jan-22	Feb-22	Mar-22	Apr-22	May-22	
Denkanikottai	14855		14855	-	-	-	-	-	
Thammampatty	5918		5918	-	-	-	-	-	
Velur	4973		4973	-	-	-	-	-	
Perundurai	14000		14000	-	-	-	-	-	
Marakkanam	18186		18186	-	-	-	-	-	
Madukkur	6506		6505.9	-	-	-	-	-	
Chinnalapatti	5964		5963.7	-	-	-	-	-	
Thenkarai	6549		6549	-	-	-	-	-	
Uthamapalayam	6877		6876.9	-	-	-	-	-	
Kaveripattinam	10856		10856	-	-	-	-	-	
Palamedu	1574		1574	-	-	-	-	-	
Thirumazhisai	2265		2265	-	-	-	-	-	
Velankkani	26082		26082	1500	1500	-	-	-	
Manachanallur	16983		16983	12100	12100	-	-	-	
Chinnalapatti	3511			1861	1861	561	561	-	
Sulur	5300			1950	1950	1950	1950	1950	
Avinasi	7583			2600	2600	2600	2600	2600	
Naravarikuppam	5208			1000	1000	520	520	221	
Karumandi Chell	16088			8300	8300	3688	3688	3688	
Harur	11181			6000	6000	3981	3981	3981	
Anaimalai	7116			180	180	123	123	123	
Anthiyur	14810			170	170	170	170	170	
Thiruvaiyaru	17500			1600	1600	1600	1600	1600	

TN ULBs	legacy waste estimated (Cu.Mtr)	Legacy waste 100% biominced (Cu.Mtr)		Under process (Balance Waste) Cu.Mtr					Remarks
		ULB	Waste	Jan-22	Feb-22	Mar-22	Apr-22	May-22	
Jalakandapuram	6036			250	250	250	250	250	
Omalur	4600			950	950	950	950	950	
Alanganallur	3186			600	600	600	600	600	
Omalur	3489			450	450	450	450	450	
Perundurai	19790			5900	5900	2790	2790	1769	
Kanniyakumari	12113			3550	3550	1574	1574	1574	
P.Velur	10474			4400	4400	4400	4400	4400	
Ammapettai	9993			3900	3900	3900	3900	1912	
Annur	9893			4900	4900	4900	4900	4900	
Periyanaickenpal	11587			5985	5985	5985	5985	5985	
Swamimalai	11251			5900	5900	5900	5900	2754	
Suleswaranpatti	10883			6685	6685	6685	6685	6685	
Gingee	14284			2207	2207	2207	2207	2207	
Thammampatti	5782			4000	4000	4000	4000	3952	
Kaliyakkavilai	1535			995	995	995	995	995	
Vazhapadi	6134			4500	4500	4500	4500	4381	
Polur	16140			11900	11900	3740	3740	2896	
Kunathur	8168			5950	5950	5950	5950	5950	
Vathalagundu	17271			12850	12850	11771	11771	11771	

National Mission for Clean Ganga
Format for submission of Monthly Progress Report in the
NGT Matter OA No. 673 of 2018 (in compliance to NGT
order dated 24.09.2020)

For the State of Tamil Nadu – May 2022

Overall status of the State:

I. Total Population: 7665951

II. Estimated Sewage Generation (MLD): 429.29 MLD

III. Details of Sewage Treatment Plant:

S.No.	Details of Sewage Treatment Plant	State	PRS
1	Existing no. of STPs and Treatment Capacity (in MLD)	9 (26.67MLD)	-
2	Capacity Utilization of existing STPs	6.10 MLD	-
3	MLD of sewage being treated through Alternate technology	3 MLD	-
4	Gap in Treatment Capacity in MLD	399.62	24.86
5	No. of Operational STPs	9	-
6	No. of Complying STPs	9	-
7	No. of Non-complying STPs	-	-

Details of each existing STP in the State & PRS

No.	Location	Existing STP Capacity	Capacity Being Utilized	Operational Status of STP	Compliance Status of STP
1	Mamallapuram TP	2.34	1.00	Operational	Complied
2	Orathanadu TP	2.30	1.30	Operational	Complied
3	Thiruchendur TP	Upgraded as Municipality			
4	Palanichettypatti TP	2.80	2.80	Operational	Complied
5	Thirumazisai TP	3.00	1.00	Operational	Complied
6	Ulundurpettai TP	Upgraded as Municipality			
7	Velankanni TP	2.33	-	Operational	Trial Run
8	Manachanallur TP S.Kannanur TP	6.41	-	Operational	Trial Run
9	Vallam TP	2.35	-	Operational	Trial Run

No.	Location	Existing STP Capacity	Capacity Being Utilized	Operational Status of STP	Compliance Status of STP
10	Perundurai TP	3.14	-	Operational	Trial Run
11	Melachokanathapuram TP	2.00	-	Operational	Trial Run
		26.67	6.10		
Septage Management					
1	Karunguzhi	0.024	0.024	Operational	
2	Periyanaikanpalayam	0.030	0.03	Operational	
3	Chengam TP	0.020	-	Operational	Trial Run
4	Alangayam TP	0.015	-	Operational	Trial Run
5	Mudukulathur TP	0.015		Operational	Trial Run
		0.104	0.054		
TOTAL		26.774	6.154		

Details of under construction STPs in the State & PRS

Sl. No.	Location	Capacity of the plant in MLD	Physical Progress in %	Status of I&D or House sewer connections	Completion Timeline
1	Sriperumbudur TP	8.50	90% completed	5100/6000	31.07.2023
2	Thiruporur TP	4.02	90% Completed(UGSS)	3936/4479	30.9.2022
3	Ponneri TP	Upgraded as Municipality			
	Total	12.52		9036/10479	
Septage Management					
1	Jalakandapuram TP	0.015	98% completed	-	30.06.2022
2	Pennagaram TP	0.015	95% completed	-	30.06.2022
3	Kaveripattinam TP	0.015	95% completed	-	30.06.2022
4	Kurumbalur TP	0.010	87% completed	-	30.06.2022
5	Pennadam TP	0.010	80% completed	-	30.06.2022
Total		0.080			

Details of proposed STPs in the State & PRS

S. No	Name of the ULB	STP/ FSTPs	STP/ FSTPs capacity in MLD/K LD	Status of DPR Preparation	Status of DPR approval	Status of award of tender	Designated nodal Agency	Treatment Technology along with firm completion timelines	Remarks
1	Musiri TP	Upgraded as Municipality							
2	Sirugamani TP	-	-	DPR Stage	-	-	PWD	-	DPR is under preparation by WAPCOS/ PWD.
3	Mohanur TP	-	-	DPR Stage	-	-	PWD	-	"
4	Velur TP	-	-	DPR Stage	-	-	PWD	-	"
5	Punjai Pugalur TP	Upgraded as Municipality							
6	Bhavani sagar TP	-	-	DPR Stage	-	-	PWD	-	"
7	Sirumugai TP	-	-	DPR Stage	-	-	PWD	-	"
8	Madathukulam TP	-	-	DPR Stage	-	-	PWD	-	"
9	Omalur TP	-	-	DPR Stage	-	-	PWD	-	"
10	Poolampatty TP	-	-	DPR Stage	-	-	PWD	-	"
11	Kuthalam TP	-	-	DPR Stage	-	-	PWD	-	"
12	Thirukattupalli TP	-	-	DPR Stage	-	-	PWD	-	"
13	Thiruvaiyaru TP	-	-	DPR Stage	-	-	PWD	-	"
14	Pethanaickenpalayam TP	-	-	DPR completed	-	-	CTP	-	Tamilnadu Water Investment Company (M/s. TWIC) has been appointed as consultant for preparation of DPR. DPR submitted on 15.2.2022 by TWIC. DPR under scrutiny
15	Yethapur TP	-	-	DPR completed	-	-	CTP	-	"

S. No	Name of the ULB	STP/ FSTPs	STP/ FSTPs capacity in MLD/K LD	Status of DPR Preparation	Status of DPR approval	Status of award of tender	Designated nodal Agency	Treatment Technology along with firm completion timelines	Remarks
16	Belur TP	-	-	DPR completed	-	-	CTP	-	"
17	Srivaikundam TP	-	-	DPR completed	-	-	CTP	-	"
18	Authoor TP	-	-	DPR completed	-	-	CTP	-	"
19	Eral TP	-	-	DPR completed	-	-	CTP	-	"
20	Alwarthirunagari TP	-	-	DPR completed	-	-	CTP	-	"
21	Then Thiruperaai TP	-	-	DPR completed	-	-	CTP	-	"
22	Arumuganeri TP	-	-	DPR completed	-	-	CTP	-	"
23	Mukkudal TP	-	-	DPR completed	-	-	CTP	-	The SBM 2.0 2 nd State High Powered Committee meeting held on 26.02.2022 has approved to establish Decentralised STP and DEWATS method. Administrative sanction issued on 21.03.2022 and works are in various stages
24	Gopalasamudram TP	-	-	DPR completed	-	-	CTP	-	
25	Kallidaikurichi TP	-	-	DPR completed	-	-	CTP	-	
26	Cheranmahadevi TP	-	-	DPR completed	-	-	CTP	-	
27	Veeravanallur TP	-	-	DPR completed	-	-	CTP	-	
28	Patthamadai TP	-	-	DPR completed	-	-	CTP	-	
29	Mela Seval TP	-	-	DPR completed	-	-	CTP	-	
30	Naranammalpuram TP						CTP		

IV. **Solid Waste Management:**

- Total number of Urban Local Bodies and their Population – **State – 470 & PRS - 27**
- Current Municipal Solid Waste Generation (**State - 1805 MT & PRS – 107.80 MT**)
- Number, installed capacity and utilization of existing MSW processing facilities in TPD (bifurcated by type of processing eg- Waste to Energy

(Tonnage and Power Output), Compost Plants (Windrow, Vermi, decentralized pit composting), biomethanation, MRF etc

State	PRS
Total MSW generated - 1805 TPD	Total MSW generated - 107.80 TPD
Total MSW processed - 1573 TPD	Total MSW processed - 93.75 TPD
Gap in processing - 232 TPD	Gap in processing - 14.05 TPD

SN	Description	State			PRS		
		Nos	Installed Capacity MT	Utilization Capacity TPD	Nos	Installed Capacity MT	Utilization Capacity TPD
1	Windrow & Vermi Composting	673	801	801	39	77	77
2	De-Centralised	39	111	111	4	7	7
3	Bio-Gas / Bio-Methanation	18	37	37	1	10	10
4	RRC	489	499	499	27	36	36

- Action plan to bridge gap between Installed Capacity and Current Utilization of processing facilities (if Gap > 20%)

State & PRS – Waste to energy plants are to be proposed on cluster basis.

- No. and capacity of C&D waste processing plants in TPD (existing, proposed and under construction) **(State & PRS)**
- Total no. of wards, no. of wards having door to door collection service, no. of wards practicing segregation at source

State	PRS
Total no. of wards - 7619 Door to Door collection – 7314 Source segregation – 6857	Total no. of wards - 465 Door to Door collection – 465 Source segregation – 418

- Details of MSW treatment facilities proposed and under construction (no., capacity, and technology)
- ✓ **So far 7 Incinerators has been completed remaining 2 Nos are under progress.(Trail run)**

- ✓ **So far 9 Pyrolysis has been completed remaining 1 No are under progress. (Trail run)**
- ✓ **For remaining Town Panchayats waste to energy plants are to be proposed on cluster basis.**
- No. and area (in acres) of uncontrolled garbage dumpsites and Sanitary Landfills.
- No. and area (in acres) of legacy waste within 1km buffer of both side of the rivers
- No. of drains falling into rivers and no. of drains having floating racks/screens installed to prevent solid waste from falling into the rivers.

Status of ULB wise Management of Solid Waste

STATE

ULB	Total MSW generation in TPD	Total MSW being processed in TPD	Existing MSW Facilities	Plant Capacity of the existing MSW facilities	Proposed MSW Facilities & Completion Timeline
490	1805	1573	1.windrow & Vermi compost	801 TPD	Waste to energy plants are to be proposed on cluster basis
			2.Decentralized composting	111 TPD	
			3. Biogas	37 TPD	
			4.Incinerator	Under construction will be completed before April 2022	
			5.Pyrolysis	Under construction will be completed before March 2022	

PRS

ULB	Total MSW generation in TPD	Total MSW being processed in TPD	Existing MSW Facilities	Plant Capacity of the existing MSW facilities	Proposed MSW Facilities & Completion Timeline
29	107.80	93.75	1.windrow & Vermi Compost 2. De-Centralized composting 3. Biogas	77 MT 7 MT 10 MT	Waste to energy plants are to be proposed on cluster basis

V. Bio-medical Waste Management:

- Total Bio-medical generation (State & PRS):
- No. of Hospitals and Health Care Facilities:
- Status of Treatment Facility/ CBMWTF:

VI. Hazardous Waste Management:

- Total Hazardous Waste generation (**State & PRS**):
- No. of Industries generating Hazardous waste
- Treatment Capacity of all TSDFs
- Avg. Quantity of Hazardous waste reaching the TSDFs and Treated
- Details of on-going or proposed TSDF

VII. Plastic Waste Management:

- Total Plastic Waste generation **State - 102 TPD & PRS – 6.2 TPD**
- Treatment/ Measures adopted for reduction or management of plastic waste:

Recyclable/ Saleable plastics are been sold to authorized vendors

Non- saleable plastics are been sent to cement factories and are used as a component for laying roads

Waste to energy plants are to be proposed on cluster basis

- VIII. Details of Alternate Treatment Technology being adopted by the State/UT
- IX. Identification of polluting sources including drains contributing to river pollution and action as per NGT order on insitu treatment:
- X. Details of Nodal Officer appointed by Chief Secretary in the State/UT:
- XI. Details of meetings carried under the Chairmanship Chief of Secretary in the State/UT:
- XII. Latest water quality of polluted river, its tributaries, drains with flow details and ground water quality in the catchment of polluted river;
- XIII. Ground water regulation:
- XIV. Good irrigation practices being adopted by the State:
- XV. Rain Water Harvesting:
- XVI. Demarcation of Floodplain and removal of illegal encroachments:
- XVII. Maintaining minimum e-flow of river:
- XVIII. Plantation activities along the rivers:

- XIX. Development of biodiversity park:
- XX. Reuse of Treated Water:
- XXI. Model River being adopted by the State & Action Proposed for achieving the bathing quality standards:
- XXII. Status of Preparation of Action Plan by the 13 Coastal States:
- XXIII. Regulation of Mining Activities in the State/UT:
- XXIV. Action against identified polluters, law violators and officers responsible for failure for vigorous monitoring.

***Note: Incremental progress made by the State/UT in each activity to be provided.**

From
Director,
Rural Development and Panchayat Raj,
Panagal Building, Saidapet,
Chennai 600 015.

To
The Chairman,
Tamil Nadu Pollution Control Board,
76, Mount Salai, Guindy,
Chennai - 600 032.

Roc. No.16503/2018/SBM(G)-3 dt.7.06.2022.

Sir,

Sub: TNPCB - Environment Control - Hon'ble National Green Tribunal OA No. 673/2018 - "Rejuvenation of Polluted River Stretches " - Monthly Progress for the month of May-2022 – Sent - Regarding.

Ref: 1. Additional Chief Secretary to Government, Rural Development and Panchayat Raj, Letter No.3870/CGS.1/2020-3, Dated:25.07.2020.
2. Reports received from the Districts.

I invite your kind attention to the references cited.

In the reference 1st cited, Government have requested to send an Action Taken Report in the prescribed format (as requested by the Central Pollution Control Board / Government of India) to the Chairman, Tamil Nadu Pollution Control Board, so as to consolidate the same for onward transmission to the Central Pollution Control Board / Government of India for compliance of the order of the National Green Tribunal in O.A.673 of 2018.

In this connection, a consolidated monthly progress report for the month of May-2022 in the prescribed format is sent herewith for kind reference and information.

Encl: Format.

Director.

Copy:

Principal Secretary to Government,
Rural Development and Panchayat Raj Department,
Secretariat, Chennai – 09.

Rural Development and Panchayat Raj.

National Mission for Clean Ganga

Format for submission of Monthly Progress Report in the NGT Matter OA No. 673 of 2018 (in compliance to NGT order dated 24.09.2020) for the Month of May-2022

Overall status of the State:

- I. Total Population: Rural Population separately: 4,04,86,223
- II. Estimated Sewage Generation (MLD): 1130

III.Details of Sewage Treatment Plant:

S.No.	Details of Sewage Treatment Plant	State	PRS
1	Existing no. of STPs and Treatment Capacity (in MLD)	-	-
2	Capacity Utilization of existing STPs	-	-
3	MLD of sewage being treated through Alternate technology	749	1.56
4	Gap in Treatment Capacity in MLD(Grey water)	381	0
5	No. of Operational STPs	-	-
6	No. of Complying STPs	-	-
7	No. of Non-complying STPs	-	-

*Gap will be addressed by construction of individual soakpit in phased manner, priority will be given to water body areas.

Details of each existing STP in the State & PRS

No.	Location	Existing STP Capacity	Capacity Being Utilized	Operational Status of STP	Compliance Status of STP
NIL					
Total					

Details of under construction STPs in the State & PRS

No.	Location	Capacity of the plant in MLD	Physical Progress in %	Status of I&D or House sewer connections	Completion Timeline
NIL					
Total					

Details of proposed STPs in the State & PRS

No.	Location	Capacity of the STP proposed in MLD	Status of Project (at DPR Stage/ Under Tendering/ Work to be Awarded)	Likely Date of Completion
NIL				
Total				

Details of proposed STPs in the State

No.	Location	Capacity of the STP proposed in MLD	Status of Project (at DPR Stage/ Under Tendering/ Work to be Awarded)	Likely Date of Completion
NIL				
Total				

IV. Details of Industrial Pollution:

- No. of industries in the State & PRS:
- No. of water polluting industries in the State & PRS:
- Quantity of effluent generated from the industries in MLD: -
- Quantity of Hazardous Sludge generated from the Industries in TPD: -
- Number of industrial units having ETPs in State & PRS:
- Number of industrial units connected to CETP:
- Number and total capacity of ETPs (details of existing/ under construction / proposed)
- Compliance status of the ETPs:
- Number and total capacity of CETPs (details of existing/ under construction / proposed)
- Status of compliance and operation of the CETPs

Town	No. of industries	Industrial discharge	Status of ETPs	Status of CETPs (existing, under construction & proposed)

V. Solid Waste Management:

- Total number of Rural Local Bodies and their Population: 12525 Village Panchayats, Population 4,04,86,223
- Current Municipal Solid Waste Generation (**State & PRS**): **1272 TPD & 8.30 TPD**

- Number, installed capacity and utilization of existing MSW processing facilities in TPD (bifurcated by type of processing eg- Waste to Energy (Tonnage and Power Output), Compost Plants (Windrow, Vermi, decentralized pit composting), biometanation, MRF etc **(State & PRS) : 12525 & 31**
- Action plan to bridge gap between Installed Capacity and Current Utilization of processing facilities (if Gap > 20%) **(State & PRS)**
- No. and capacity of C&D waste processing plants in TPD (existing, proposed and under construction) **(State & PRS)**
- Total no. of wards, no. of wards having door to door collection service, no. of wards practicing segregation at source **(State & PRS) : 12525 Village Panchayats & 31 Village Panchayats.**
- Details of MSW treatment facilities proposed and under construction (no., capacity, and technology) **(State & PRS) MCC – 321&1 (proposed)**
- No. and area (in acres) of uncontrolled garbage dumpsites and Sanitary Landfills- nil
- No. and area (in acres) of legacy waste within 1km buffer of both side of the rivers- nil
- No. of drains falling into rivers and no. of drains having floating racks/screens installed to prevent solid waste from falling into the rivers.

Status of ULB wise Management of Solid Waste

ULB	Total MSW generation in TPD	Total MSW being processed in TPD	Existing MSW facilities	Utilization Capacity of the existing MSW facilities	Proposed MSW Facilities & Completion Timeline
Total					

VI. Bio-medical Waste Management:

- Total Bio-medical generation (State & PRS):
- No. of Hospitals and Health Care Facilities:
- Status of Treatment Facility/ CBMWTF:

VII. Hazardous Waste Management:

- Total Hazardous Waste generation **(State & PRS):**
- No. of Industries generating Hazardous waste

- Treatment Capacity of all TSDFs
- Avg. Quantity of Hazardous waste reaching the TSDFs and Treated
- Details of on-going or proposed TSDF

VIII. Plastic Waste Management:

- Total Plastic Waste generation (State & PRS):
- Treatment/ Measures adopted for reduction or management of plastic waste: Plastic Shredding units available at 1 per Districts provided under SWM Scheme.

- IX. Details of Alternate Treatment Technology being adopted by the State/UT
- X. Identification of polluting sources including drains contributing to river pollution and action as per NGT order on insitu treatment:
- XI. Details of Nodal Officer appointed by Chief Secretary in the State/UT:
- XII. Details of meetings carried under the Chairmanship Chief of Secretary in the State/UT:
- XIII. Latest water quality of polluted river, its tributaries, drains with flow details and ground water quality in the catchment of polluted river;
- XIV. Ground water regulation:
- XV. Good irrigation practices being adopted by the State:
- XVI. Rain Water Harvesting:
- XVII. Demarcation of Floodplain and removal of illegal encroachments:
- XVIII. Maintaining minimum e-flow of river:
- XIX. Plantation activities along the rivers:
- XX. Development of biodiversity park:
- XXI. Reuse of Treated Water:
- XXII. Model River being adopted by the State & Action Proposed for achieving the bathing quality standards:
- XXIII. Status of Preparation of Action Plan by the 13 Coastal States:
- XXIV. Regulation of Mining Activities in the State/UT:
- XXV. Action against identified polluters, law violators and officers responsible for failure for vigorous monitoring

**GOVERNMENT OF TAMILNADU
WATER RESOURCES DEPARTMENT**

From
Er. S. Prabakaran, B.E.,
Chief Engineer, WRD,
State Ground & Surface Water
Resources Data Centre,
Tharamani, Chennai - 600 113.
Email: cegwchennai@gmail.com

To
Deputy Director,
Tamil Nadu Pollution Control Board,
76, Mount Salai,
Guindy,
Chennai – 600 032.

Lr. No: / RRC / AGC /2022 Dated: 07.07.2022

Sir,

Sub: NGT Case No 673/2018- Central Monitoring Committee (CMC) - Tamil Nadu Pollution Control Board (TNPCB) - Submission of Monthly Progress Report in the prescribed formats for the month of **May 2022**, for **Five Polluted river stretches**- Submission - Regarding.

Ref: 1. Email received from Deputy Director, TNPCB dated: 27.05.2022.

The monthly progress reports of the following polluted river stretches are herewith enclosed in the prescribed format for your information and further action please.


- (i) **Sirumugai to Kalingarayan in River Bhavani**
- (ii) **Thathayampatti to T.Konagapadi in Sarabanga River**
- (iii) **Manivilundhan to Thiyaganur in Vasista River**
- (iv) **Salem to Papparapatti in Thirumanimutharu River**
- (v) **Mettur to Mayiladuthurai in Cauvery River**

(Sd/-) Er. S. Prabakaran,
Chief Engineer (SG & SWRDC).
Tharamani, Chennai -113

Enclosure: Monthly progress reports

Copy presented to the Additional Chief Secretary, to Government, WRD, Fort. St. George, Chennai-9

Copy to Engineer-in-Chief and Chief Engineer (General), WRD, Chepauk, Chennai- 5


for Chief Engineer (SG & SWRDC)
Tharamani, Chennai -113.

XIII. Latest water quality of polluted river, its tributaries, drains with flow details and ground water quality in the catchment of polluted river;

The general distribution of ground water quality varies between Good to moderate level. Especially Nilgiris is having good quality water.

The State Ground and Surface Water Resources Data centre is having water quality data for number of locations. Moreover this department is mainly concerned with the analysis of inorganic parameters and hence TDS is being used as a vital tool in determining the quality of water as Good, Moderate or poor quality. But to identify pollution in an area, the pollution parameters such as Dissolved Oxygen (DO), Biochemical Oxygen Demand (BOD), Chemical Oxygen Demand (COD), Total Coliform, Faecal Coliform has to be measured. With the water quality data available in this Department, it can be inferred whether ground water of a particular area is suitable for drinking or not.

Hence it is suggested that water samples may be collected along this river stretch and analysis may be performed for pollution parameters to identify the extent of pollution.

XIV. Ground water regulation:

1.	Control of illegal Groundwater Abstraction	• For effective management of Ground Water, action is being initiated against illegally operating companies as Per Honorable Madras High Court order passed under WP No.16299 / 2018. Totally 683 packaged drinking water firms who were illegally operating have been sealed and closed. • A Comprehensive Groundwater (Management and Development) Act., to regulate and Manage the extraction of Groundwater is under active consideration of the Government. The draft act has been approved by the high level technical committee headed by the Chief Secretary. Further action to enact the law is under process.
----	---	--

XV. Good irrigation practices being adopted by the State:

Awareness meeting are conducted under TNIAMP, ADB & State Funds. In some parts of the reach, DRIP irrigation is practiced.

XVI. Rain Water Harvesting:

Existing structure	Ongoing works	Proposed works
28	Check dam – 4 Nos. Recharge shaft – 15 Nos.	--

XVII. Demarcation of Floodplain and removal of illegal encroachments:

Drone Survey has been completed by WAPCOS in January 2021. The draft DPR prepared by M/S WAPCOS for conducting the above survey for identification of flood plain zones and area for afforestation to maintain Bio Diversity has been submitted and is under the scrutiny of PWD. The tentative cost of the DPR is around 2 crores.

55 nos. of encroachments are to be removed which belong to fishing community. Recommendations for alternate land has been sent to Secretary to Government Revenue department by Commissioner for Revenue administration vides letter no F.2/41632/2005/Dt.15.2.2006.

XVIII. Maintaining minimum e-flow of river:

An E-flow of 16,179 cusecs (including Irrigation purpose) was maintained in the river Bhavani during the month of **May 2022**.

XIX. Plantation activities along the rivers:

It is proposed to plant around 86,500 samplings under Nadanthai Vaazhi Cauvery for which a draft DPR has been prepared by M/s.WAPCOS and is under the scrutiny of PWD. Plantation work will be completed in March 2022.

XX. Development of biodiversity park:

Drone Survey has been completed by M/s.WAPCOS in January 2021. This is proposed to be taken up under Nadanthai Vaazhi Cauvery for which a draft DPR prepared by M/s.WAPCOS and has been submitted and is under the scrutiny of PWD. This work will be completed in March 2022.


For Chief Engineer (SG&SWRDC)

XIII. Latest water quality of polluted river, its tributaries, drains with flow details and ground water quality in the catchment of polluted river;

The State Ground and Surface Water Resources Data Centre is having monitoring wells for observation of ground water quality in Danishpet, Omalur, Idaipadi, Thevur and Tharamangalam areas. While considering the Total dissolved solids of this stretch, it is found to vary between 399mg/L to 1885 mg/L. Danishpet is having TDS of good quality whereas the rest of the places having TDS value in the range of moderate quality.

The State Ground and Surface Water Resources Data centre is having water quality data for the lesser number of locations. Moreover this department is mainly concerned with the analysis of inorganic parameters and hence TDS is being used as a vital tool in determining the quality of water as Good, Moderate or poor quality. But to identify pollution in an area, the pollution parameters such as Dissolved Oxygen (DO), Biochemical Oxygen Demand (BOD), Chemical Oxygen Demand (COD), Total Coliform, Faecal Coliform have to be measured. With the water quality data available in this Department, it can be inferred whether ground water of a particular area is suitable for drinking or not.

Hence it is suggested that surface water samples may be collected along this river stretch and analysis may be performed for pollution parameters to identify the extent of pollution.

XIV. Ground water regulation:

1.	Control of illegal Groundwater Abstraction	• For effective management of Ground Water, action is being initiated against illegally operating companies as Per Honorable Madras High Court order passed under WP No.16299 / 2018. Totally 683 packaged drinking water firms who were illegally operating have been sealed and closed. • A Comprehensive Groundwater (Management and Development) Act., to regulate and Manage the extraction of Groundwater is under active consideration of the Government. The draft act has been approved by the high level technical committee headed by the Chief Secretary. Further action to enact the law is under process.
----	---	--

XV. Good irrigation practices being adopted by the State:

Awareness meeting are conducted under TNIAMP, ADB & State Funds. In some parts of the reach DRIP irrigation is practiced.

XVI. Rain Water Harvesting:

Existing structure	Ongoing works	Proposed works
5	2	10 Recharge wells

XVII. Demarcation of Flood plain and removal of illegal encroachments:

Drone Survey has been completed by WAPCOS in January 2021. The draft DPR prepared by M/s.WAPCOS for conducting the above survey for identification of flood plain zones and area for afforestation to maintain Bio Diversity has been submitted and the scrutinization of DPR is done by NRCD during March 2022 and finalization of DPR will be completed by end of this month and submitted to ministry of Jal Sakthi, Gol for funding. The tentative cost of the DPR is around 2 crores. Encroachment if any identified during the survey will be evicted and other management works will be completed and rehabilitation and resettlement will be done.

XVIII. Maintaining minimum e-flow of river:

This river is only a flood carrier. The sewage water enters in to the river in Edapaddi Municipality, Omalur Town Panchayat and Poolampatti Town Panchayat. The above treatment plants are proposed under Nadanthai Vaazhi Cauvery for which a draft DPR has been prepared by M/s.WAPCOS and the scrutinization of DPR is done by NRCD during March 2022 and finalization of DPR will be completed by end of this month and submitted to ministry of Jal Sakthi, Gol for funding. E flow will be maintained in this river after completion sewage treatment plants, as the treated water will flow as environmental flow.

XIX. Plantation activities along the rivers:

It is proposed to plant around 32,400 samplings under Nadanthai Vaazhi Cauvery for which a draft DPR has been prepared by M/s.WAPCOS and has been submitted and scrutinization of DPR is done by NRCD during March 2022 and finalization of DPR will be completed by end of this month and submitted to ministry of Jal Sakthi, Gol for funding.

XX. Development of biodiversity park:

Drone Survey has been completed by M/s.WAPCOS in January 2021. A draft DPR prepared by M/s.WAPCOS and has been submitted and the scrutinization of DPR is done by NRCD during March 2022 and finalization of DPR will be completed by end of this month and submitted to ministry of Jal Sakthi, Gol for funding.


For Chief Engineer (SG&SWRDC)

XIII. Latest water quality of polluted river, its tributaries, drains with flow details and ground water quality in the catchment of polluted river;

The SG&SWRDC is having monitoring wells for observing water quality data for the areas Papanaiickenpatti, Yethapur, Athur and Thalaivasal. The analytical reports of the ground water analysis of these areas reveals that water quality is of the order of both good and moderate. The TDS values of these areas ranging between 336 to 1029 mg/L.

The State Ground and Surface Water Resources Data centre is having water quality data for lesser number of locations. Moreover this department is mainly concerned with the analysis of inorganic parameters and hence TDS is being used as a vital tool in determining the quality of water as Good, Moderate or poor quality. But to identify pollution in an area, the pollution parameters such as Dissolved Oxygen(DO), Biochemical Oxygen Demand (BOD), Chemical Oxygen Demand (COD), Total Coliform, Faecal Coliform has to be measured. With the water quality data available in this Department, it can be inferred whether ground water of a particular area is suitable for drinking or not.

Hence it is suggested that water samples may be collected along this river stretch and analysis may be performed for pollution parameters to identify the extent of pollution.

XIV. Ground water regulation:

1.	Control of illegal Groundwater Abstraction	• For effective management of Ground Water, action is being initiated against illegally operating companies as Per Honorable Madras High Court order passed under WP No.16299 / 2018. Totally 683 packaged drinking water firms who were illegally operating have been sealed and closed. • A Comprehensive Groundwater (Management and Development) Act., to regulate and Manage the extraction of Groundwater is under active consideration of the Government. The draft act has been approved by the high level technical committee headed by the Chief Secretary. Further action to enact the law is under process.
-----------	---	--

XV. Good irrigation practices being adopted by the State:

Awareness meeting are conducted under TNIAMP, ADB & State Funds. In some parts of the reach DRIP irrigation is practiced.

XVI. Rain Water Harvesting:

Existing structure	Ongoing works	Proposed works
16	---	---

XVII. Demarcation of Floodplain and removal of illegal encroachments:

No Flood plains zones have been identified. No Encroachment has also been identified in the stretch. In case of any encroachments reported in the future by Revenue department, action will be taken for immediate eviction.

XVIII. Maintaining minimum e-flow of river:

This river is only a flood carrier. But the sewage water enters in to the river in Attur and Narasingapuram Municipality. After completion sewage treatment plants in the above location, the treated water will flow as environment flow.

XIX. Plantation activities along the rivers:

There is no proposal at present.

XX. Development of biodiversity park:

There is no proposal at present.


For Chief Engineer (SG&SWRDC)

Format for Submission of Monthly Progress Report by States/ UTs
(Hon'ble NGT in the matter of OA No. 673/2018 dated 06.12.2019)
for the Month of **May 2022** for TNPWD WRD

Reach: Mettur to Mayiladuthurai stretch in Cauvery River

XIII. Latest water quality of polluted river, its tributaries, drains with flow details and ground water quality in the catchment of polluted river;

This river stretch comprises districts of Dharmapuri, Erode, Salem, Namakkal, Karur, Trichy, Cuddalore and Thanjavur. The State Ground water Department is having ground water quality data for the areas of Dharmapuri, Mettur, Bhavani, Salem, Paramathivelur, Namakkal, Kumarapalayam, Karur, Erode, Musiri, Trichy, Kulithalai, Thanjavur, Kumbakonam and Mayiladuthurai. While considering the TDS value of Dharmapuri taluk it is found to vary between 523 to 2096 mg/L and the quality of ground water lies between Moderate to poor. In case of Bhavani river the TDS values ranging between Good to moderate. While reviewing WQ data of Salem, the TDS values found to vary between 412 to 2845mg/L, the available ground water in Salem is having good, moderate and poor quality with major proportion moderate ground water. The water quality data of Namakkal shows the TDS values exceed even 6000mg/L in some places with wide distribution of moderate water quality. While reviewing the water quality data of Trichy and Musiri the water quality is found to vary between good and moderate in most of the places with very few places having poor quality. Most of the locations in Cuddalore and Thanjavur are having good quality water. Few places of Cuddalore having TDS of the order of 5000 to 6000mg/L.

The State Ground and Surface Water Resources Data centre is having water quality data for lesser number of locations. Moreover this department is mainly concerned with the analysis of inorganic parameters and hence TDS is being used as a vital tool in determining the quality of water as Good, Moderate or poor quality. But to identify pollution in an area, the pollution parameters such as Dissolved Oxygen(DO), Biochemical Oxygen Demand (BOD), Chemical Oxygen Demand (COD), Total Coliform, Faecal Coliform has to be measured. With the water quality data available in this Department, it can be inferred whether ground water of a particular area is suitable for drinking or not.

Hence it is suggested that water samples may be collected along this river stretch and analysis may be performed for pollution parameters to identify the extent of pollution.

XIV. Ground water regulation:

1.	Control of illegal Groundwater Abstraction	• For effective management of Ground Water, action is being initiated against illegally operating companies as Per Honorable Madras High Court order passed under WP No.16299 / 2018. Totally 683 packaged drinking water firms who were illegally operating have been sealed and closed. • A Comprehensive Groundwater (Management and Development) Act., to regulate and Manage the extraction of Groundwater is under active consideration of the Government. The draft act has been approved by the high level technical committee headed by the Chief Secretary. Further action to enact the law is under process.
-----------	---	--

XV. Good irrigation practices being adopted by the State:

Awareness meeting are conducted under TNIAMP, ADB & State Funds. In some parts of the reach DRIP irrigation is practiced.

XVI. Rain Water Harvesting:

Existing structure	Ongoing works	Proposed works
44	10	29

XVII. Demarcation of Floodplain and removal of illegal encroachments:

Drone Survey has been completed by M/s.WAPCOS in January 2021. The draft DPR prepared by M/s.WAPCOS for conducting the above survey for identification of flood plain zones and area for afforestation to maintain Bio Diversity has been submitted and the scrutinization of DPR is done by NRCD during March 2022 and finalization of DPR will be completed by end of this month and submitted to ministry of Jal Sakthi, Gol for funding.

The tentative cost of the DPR is around 20 crores. Encroachment if any identified during the survey will be evicted and other management works will be completed by March 2022 after rehabilitation and resettlement.

XVIII. Maintaining minimum e-flow of river:

Mettur dam is opened for irrigation from June 12th to January 28th based on availability of water every year. It is opened for drinking purpose in the remaining days, during the monsoon period at flood time the maximum flood discharge in the river has been 284606 cusecs on 08.07.1961. Usually a monthly minimum average E flow of 0.10 TMC is maintained. The E flow is maintained for more than 8 months. During the month of **May 2022** an E Flow of **0.261** TMC was maintained.

XIX. Plantation activities along the rivers:

It is proposed to plant around 1,44,500 samplings under Nadanthai Vaazhi Cauvery for which a draft DPR prepared by M/s.WAPCOS and has been submitted and the scrutinization of DPR is done by NRCD during March 2022 and finalization of DPR will be completed by end of this month and submitted to ministry of Jal Sakthi, Gol for funding.

XX. Development of biodiversity park:

Drone survey has been completed by M/s.WAPCOS in January 2021. A draft DPR prepared by M/s.WAPCOS and has been submitted and the scrutinization of DPR is done by NRCD during March 2022 and finalization of DPR will be completed by end of this month and submitted to ministry of Jal Sakthi, Gol for funding.


For Chief Engineer (SG&SWRDC)

Format for Submission of Monthly Progress Report by States/ UTs
(Hon'ble NGT in the matter of OA No. 673/2018 dated 06.12.2019)
for the Month of **May 2022** for TNPWD WRD
Reach: Salem to Papparpatti in Thirumanimutharu River

XIII. Latest water quality of polluted river, its tributaries, drains with flow details and ground water quality in the catchment of polluted river;

For this stretch the SG& SWRDC having monitoring wells for observation ground water quality in Salem, Attayampatti, and palapatti areas.

From the observed data it is inferred that the quality of water is in moderate level i.e in these places TDS value ranges between 500 to 2000mg/L.

The State Ground and Surface Water Resources Data centre is having water quality data for lesser number of locations. Moreover this department is mainly concerned with the analysis of inorganic parameters and hence TDS is being used as a vital tool in determining the quality of water as Good, Moderate or poor quality. But to identify pollution in an area, the pollution parameters such as Dissolved Oxygen(DO), Biochemical Oxygen Demand(BOD), Chemical Oxygen Demand(COD), Total Coliform, Faecal Coliform has to be measured. With the water quality data available in this Department, it can be whether ground water of a particular area is suitable for drinking or not.

Hence it is suggested that water samples may be collected along this river stretch and analysis may be performed for pollution parameters to identify the extent of pollution.

XIV. Ground water regulation:

1.	Control of illegal Groundwater Abstraction	- For effective management of Ground Water, action is being initiated against illegally operating companies as Per Honorable Madras High Court order passed under WP No.16299 / 2018. Totally 683 packaged drinking water firms who were illegally operating have been sealed and closed. - A Comprehensive Groundwater (Management and Development) Act., to regulate and Manage the extraction of Groundwater is under active consideration of the Government. The draft act has been approved by the high level technical committee headed by the Chief Secretary. Further action to enact the law is under process.
----	---	---

XV. Good irrigation practices being adopted by the State:

Awareness meeting are conducted under TNIAMP, ADB & State Funds. In some parts of the reach DRIP irrigation is practiced.

XVI. Rain Water Harvesting:

Existing structure	Ongoing works	Proposed works
6	----	14 (Recharge well structures)

XVII. Demarcation of Flood plain and removal of illegal encroachments:

Drone Survey has been completed by M/s.WAPCOS in January 2021. The draft DPR prepared by M/s.WAPCOS for conducting the above survey for identification of flood plain zones and area for afforestation to maintain Bio Diversity has been submitted and scrutinization of DPR will be completed by end of this month and submitted to ministry of Jal Sakthi, Gol for funding. The tentative cost of the DPR is around 2 crores. Encroachment if any identified during the survey will be evicted and other management works will be done.

XVIII. Maintaining minimum e-flow of river:

This river is only a flood carrier. The sewage water enters in to the river in Salem Corporation. Treatment plants have been proposed under Nadanthai Vaazhi Cauvery. A draft DPR prepared by M/s.WAPCOS has been submitted and scrutinization of DPR is done by NRCD during March 2022 and finalization of DPR will be completed by end of this month and submitted to ministry of Jal Sakthi, Gol for funding. E flow will be maintained in this river after completion sewage treatment plants, as the treated water will flow as environmental flow.

XIX. Plantation activities along the rivers:

It is proposed to plant around 42,000 samplings under Nadanthai Vaazhi Cauvery for which a draft DPR prepared by M/s.WAPCOS has been submitted and scrutinization of DPR is done by NRCD during March 2022 and finalization of DPR will be completed by end of this month and submitted to ministry of Jal Sakthi, Gol for funding.

XX. Development of biodiversity park:

Drone Survey is completed by M/s.WAPCOS in January 2021. A draft DPR prepared by M/s.WAPCOS has been submitted and scrutinization of DPR is done by NRCD during March 2022 and finalization of DPR will be completed by end of this month and submitted to ministry of Jal Sakthi, Gol for funding.



TAMIL NADU POLLUTION CONTROL BOARD

76, Mount Salai, Guindy, Chennai - 600 032.

Water Quality Status of Polluted River Stretches

**River Sarabanga - Polluted river stretches from Thathayampatti to T.Konagapadi - 15
KM - Priority-I**

Sl. No.	Name of station	Station Code No.	May-22				
			pH	D.O mg/L	BOD at 27 ⁰ C mg/L	Fecal coliform MPN/100 ml	Total coliform MPN/100 ml
1	Edappadi (River)	3024	Samples not received				

Standard limit for pH 6.5 to 8.5

Standard limit for DO 5.0 mg/l or more

Standard limit for BOD 3 mg/L or less

Standard limit for Total coliform MPN/100ml shall be 500 or less



TAMIL NADU POLLUTION CONTROL BOARD

76, Mount Salai, Guindy, Chennai - 600 032.

Water Quality Status of Polluted River Stretches

**River Thirumanimutharu - Polluted river stretches from Salem to Papparapatti - 15
KM - Priority-I**

Sl. No.	Name of station	Station Code No.	May-22				
			pH	D.O mg/L	BOD at 27 ⁰ C mg/L	Fecal coliform MPN/100 ml	Total coliform MPN/100 ml
1	Uthamasolapuram (River)	3022	7.0	0.2	13.6	310	700

Standard limit for pH 6.5 to 8.5

Standard limit for DO 5.0 mg/l or more

Standard limit for BOD 3 mg/L or less

Standard limit for Total coliform MPN/100ml shall be 500 or less



TAMIL NADU POLLUTION CONTROL BOARD

76, Mount Salai, Guindy, Chennai - 600 032.

Water Quality Status of Polluted River Stretches

**River Vasista - Polluted river stretches from Manivilundhan to Thiyaganur -
10 KM - Priority-I**

Sl. No.	Name of station	Station Code No.	May-22				
			pH	D.O mg/L	BOD at 27 ⁰ C mg/L	Fecal coliform MPN/100 ml	Total coliform MPN/100 ml
1	Thulukkanur (River)	3023	Samples not received				

Standard limit for pH 6.5 to 8.5

Standard limit for DO 5.0 mg/l or more

Standard limit for BOD 3 mg/L or less

Standard limit for Total coliform MPN/100ml shall be 500 or less

TAMIL NADU POLLUTION CONTROL BOARD

76, Mount Salai, Guindy, Chennai - 600 032.

Water Quality Status of Polluted River Stretches

**River Cauvery - Polluted river stretches from Mettur to Mayiladuthurai - 200 KM -
Priority - I**

Sl.No.	Name of station	Station Code No.	May-22				
			pH	D.O mg/L	BOD at 27° C mg/L	Fecal coliform MPN/100 ml	Total coliform MPN/100 ml
1	Mettur	50	6.6	6.4	0.6	43	94
2	Pallipalayam	51	6.2	6.1	1.6	210	430
3	Musiri Borewell	32	Samples not received				
4	Musiri Ferry Gate	31	8.6	7.2	2.2	43	120
5	Komarapalayam	3012	6.9	6.0	1.2	170	320
6	Urachikottai	3013	6.5	6.1	1.7	31	63
7	Seerampalayam	3014	6.3	6.0	0.5	27	79
8	Pugalur	3015	7.0	6.1	1.3	250	580
9	Pettavaithalai	3016	8.8	6.9	2.4	33	110
10	Kumbakonam	3017	8.2	6.8	2.6	33	79
11	Mayiladurai	3018	Samples not received				
12	R.N. Pudur	1322	7.1	6.0	1	140	330
13	Vairapalayam	1320	6.4	6.0	1.4	17	46
14	P. Velur	1323	7.0	6.2	1.4	210	390
15	Mohanur	1324	7.0	6.3	1.3	170	310
16	Thirumukkudal	1451	6.9	6.2	0.6	220	490
17	Trichy Upstream	1202	8.7	7.0	2.5	220	490
18	Trichy Downstream	1325	8.4	7.0	2.3	840	1700
19	Grand Anaicut	1203	8.0	7.1	2.2	31	63

Standard limit for pH 6.5 to 8.5

Standard limit for DO 5.0 mg/l or more

Standard limit for BOD 3 mg/L or less

Standard limit for Total coliform MPN/100ml shall be 500 or less

TAMIL NADU POLLUTION CONTROL BOARD

76, Mount Salai, Guindy, Chennai - 600 032.

Water Quality Status of Polluted River Stretches

**River Bhavani Polluted river stretches from Sirumugai to Kalingarayan - 60 KM -
Priority-IV**

Sl. No.	Name of station	Station Code No.	May-22				
			pH	D.O mg/L	BOD at 27° C mg/L	Fecal coliform MPN/100 ml	Total coliform MPN/100 ml
1	Badrakaliamman koil	1201	6.5	6.2	1.5	79	130
2	Sirumugai	1204	6.5	6.1	1.3	46	110
3	Bhavanisagar	1321	6.0	6.4	1.0	17	43
4	Bhavani	1205	7.3	6.3	0.8	110	210
5	Sathyamangalam	3019	6.2	6.2	0.7	21	46
6	Kalingarayan Canal (B5)	3020	7.5	6.2	1.7	68	150
7	Kalingarayan Canal (B10)	3021	6.9	6.2	1.0	170	410

Standard limit for pH 6.5 to 8.5

Standard limit for DO 5.0 mg/l or more

Standard limit for BOD 3 mg/L or less

Standard limit for Total coliform MPN/100ml shall be 500 or less

TAMIL NADU POLLUTION CONTROL BOARD

76, Mount Salai, Guindy, Chennai - 600 032.

Water Quality Status of Polluted River Stretches

**River Thamirabarani Polluted river stretches from Pappankulam to Arumuganeri -
80 KM - Priority-V**

Sl. No.	Name of station	Station Code No.	May-22				
			pH	D.O mg/L	BOD at 27° C mg/L	Fecal coliform MPN/100 ml	Total coliform MPN/100 ml
1	Papanasam	1159	6.8	6.5	<2	<1.8	2
2	Cheranmadevi	1160	7.1	6.4	2.4	3.6	14
3	Kokirakulam	1161	7.6	6.3	2.8	6.1	38
4	Murapanadu	1162	7.4	7.6	2.5	14.0	58
5	Thiruvidadaimarudur	1328	7.1	6.5	2.4	1.8	6
6	Ambasamudram	1329	6.5	6.3	2.0	<1.8	4
7	Authoor	1330	7.6	7.4	2.4	24.0	80
8	Eral	3025	7.8	5.0	2.3	28.0	92
9	Kallidaikurichi	3026	6.8	6.4	2.2	<1.8	4
10	Srivaikuntam	3027	7.2	6.7	2.3	18.0	60
11	Vellakovil	3028	7.7	6.2	2.6	6.1	41
12	Seevalaperi	3029	7.7	6.6	2.5	6.8	63

Standard limit for pH 6.5 to 8.5

Standard limit for DO 5.0 mg/l or more

Standard limit for BOD 3 mg/L or less

Standard limit for Total coliform MPN/100ml shall be 500 or less

